



City of Cleveland
Frank G. Jackson, Mayor

Department of Public Health
Division of Air Quality
75 Erievue Plaza, Second Floor
Cleveland, Ohio 44114-1839
216/664-2297 • Fax: 216/420-8047
www.clevelandhealth.org

**SERVING OHIO EPA AS AGENCY 13
FOR CUYAHOGA COUNTY**

**CERTIFIED MAIL 7011 3500 0000 1759 9147
RETURN RECEIPT REQUESTED**

August 14, 2013

Mark Coleman
Coleman Trucking, Inc.
3580 East 93rd Street
Cleveland, Ohio 44105

**RE: 6638 Mill Road
PROJECT ID: CL 13 2233
NOTICE OF VIOLATION FOLLOW-UP LETTER: NESHAP VIOLATIONS**

Dear Mr. Coleman:

On July 24, 2013, the Cleveland Division of Air Quality (CDAQ) issued a Notice of Violation requiring Coleman Trucking, Inc. (Coleman) to submit a corrective action plan stating how you will comply with asbestos removal operations.

CDAQ is in receipt of a corrective action plan dated August 7, 2013. The plan stated that Coleman will adapt their work practices and utilize engineering controls to comply with applicable asbestos regulations which were cited in the Notice of Violation.

The corrective action plan was received in a timely manner and appropriate steps were taken to bring the project into compliance. CDAQ has determined that no further enforcement action is warranted at this time, but reserves its right to take such action in the future if necessary.

You are expected to comply with your stated corrective actions. Failure to do so may result in referral to Ohio EPA or U.S. EPA for further enforcement action. Fulfillment of your commitments included in the corrective action plan and/or any modifications contained within this letter does not constitute a waiver of CDAQ's ability to refer this matter to Ohio EPA or U.S. EPA for further enforcement action.



CDAQ issues this letter with Ohio EPA's concurrence and does not excuse any violations of local, state and federal laws or regulations regarding air pollution control. Violations of air pollution control laws may be pursued in local court or referred to Ohio EPA or U.S. EPA for further enforcement action. Should you have any questions, please call Mike Samec at 216-420-7682. All correspondence with CDAQ must include the Ohio EPA project identification number for 6638 Mill Road: CL 13 2233.

Sincerely,

A handwritten signature in blue ink, appearing to read "Valencia White".

Valencia White
Chief of Enforcement, CDAQ

VW/ms

cc: John Paulian, Ohio EPA Central Office
Larry Tomec, Brecksville-Broadview Heights School District
See Coleman, Coleman Trucking, Inc.
L:\Data\Facilities\+ Programs\Asbestos\Sites\6638 Mill Road\2013-07-19
ROV+NEAR.docx



ment

August 6, 2013

Attn: Mike Samec

Cleveland Division of Air Quality

75 Erieview Plaza 2nd Floor

Cleveland, Ohio 44114-1839



Re: Brecksville Middle School CL13 2233

This letter is written in response to your letter dated July 24, 2013. Coleman Trucking Inc. removed all ceiling tiles in a regulated area after being wetted via airless sprayer, while under negative pressure in whole pieces, intact as not to create any breakage. The tiles were transported unbroken and stacked while still whole into a double lined dumpster for disposal. Based on your observations and comments, Coleman Trucking Inc. will adapt our work practices and utilize engineering controls to comply with your recommendations. Our amended work practices will also include adherence to the following regulations:

CTI will adequately wet all RACM exposed during cutting or disjoining operations during asbestos removal.

CTI will adequately wet the removed RACM and ensure its remains wet until collected and contained for disposal.

CTI will not discharge visible emissions to the outside air from collection, wetting and handling operations before they escape or vent to the outside air.

CTI will label the waste container storing RACM with warning signs.

If you have any question or concerns regarding this matter please feel free to contact me at

216 441-7615.

Thank you,


Mark Coleman

Vice President

cc: Larry Tomec, Brecksville-Broadview Heights School District