



State of Ohio Environmental Protection Agency

**STREET ADDRESS:**

Lazarus Government Center  
50 W Town Street, Suite 700  
Columbus, OH 43215

TELE: (614) 644-3020  
www.epa.si

OH2801512 LAKE LUCERNE CLUB CO.

**MAILING ADDRESS:**

CDBP 27 12/03/08

December 3, 2008



LAKE LUCERNE CLUB CO.  
8048 CHAGRIN RD  
CHAGRIN FALLS, OH 44023

Re: GEAUGA COUNTY  
LAKE LUCERNE CLUB CO.  
Community Water System  
PWS ID: OH2801512

**NOTICE OF VIOLATION - ACTION REQUIRED**

**Subject: Failure to Monitor Drinking Water**

Lake Lucerne Club Co. is in violation of Ohio Administrative Code Rule 3745-81-24 for failing to monitor your drinking water during the July 1, 2008 to September 30, 2008 monitoring period and/or report results for the following contaminants: TOTAL HALOACETIC ACIDS (HAA5), TOTAL TRIHALOMETHANES (TTHM)

**In order to return to compliance, Lake Lucerne Club Co. must take the following actions:**

1. Immediately collect a sample of your drinking water from the maximum residence time (location in system where age of water is oldest).
2. Submit the sample for analysis to a certified laboratory on the enclosed list.
3. Notify your customers using the enclosed instructions and public notice.
4. Complete and return the enclosed verification form to this office.

Your prompt attention to this matter is greatly appreciated. Continued noncompliance may lead to enforcement actions. If you have any questions or if the required sample was tested, please call me at (614) 644-2752.

Sarah Byerly  
Division of Drinking and Ground Waters

Enclosure: Public Notice; Public Notice Instructions and Verification Form; Laboratory List  
cc: Superintendent/Manager; DDAGW-NEDO file; DDAGW-CO file

