91 7108 2 3 3931 0972 4452

OH3500711 HENRY COUNTY REGIONAL WSI 2950 02 05/18/09

0H3500711874671 0

State of Ohio Environm

STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 644-275
www.epa

Columbus, OH 43216-1049

NOTICE OF VIOLATION – ACTION REQUIRED

May 19, 2009

CERTIFIED MAIL

Art Akeman
McClure Village
210 E North St, Po Box 340
McClure, OH 43534

Henry County
McClure Village
Community PWS
PWS ID: OH3500711
Facility ID: DS1

Subject: Violation of Maximum Contaminant Level for TOTAL TRIHALOMETHANES (TTHM)

McClure Village is in violation for exceeding the maximum contaminant level (MCL) standard of 0.080 MG/L as established in the Ohio Administrative Code (OAC) section 3745-81-12 for TTHM. Compliance with the MCL is based on a running annual average. The annual average for TTHM during the First Quarter of 2009 time period is 0.100 MG/L.

To address the MCL violation, McClure Village is required to take the following actions:

1. Notify your customers within 30 days using the enclosed instructions and public notice.
2. Complete and send a verification form with a copy of the public notice to the above mailing address within ten days after issuance.
3. Perform quarterly monitoring for TTHM during each calendar quarter (January 1 – March 31; April 1 – June 30; July 1 – September 30; October 1 to December 31).
4. Consult with your Ohio EPA district representative to discuss your options for coming into compliance and establishing a compliance schedule or comply with any existing enforcement action that has been issued to you.

Your prompt attention to this matter is greatly appreciated. Continued noncompliance may lead to enforcement actions. If you have any questions or wish to change the public notice, please call me at (614) 644-2752.

Sincerely,

Sarah Byerly,
Division of Drinking and Ground Waters

Enclosure: Public Notice, Verification Form

cc: DDAGW File; NWDO File; Henry County Health Department

DRINKING WATER NOTICE

McClure Village Has Levels of TOTAL TRIHALOMETHANES (TTHM) Above Drinking Water Standards

Our water system recently violated the maximum contaminant level (MCL) for TTHM. The average level of TTHM over the last four quarters was 0.100 MG/L. The standard for TTHM is 0.080 MG/L.

What should I do?

- **You do not need to use an alternative (e.g., bottled) water supply.** However, if you have specific health concerns, consult your doctor.

What does this mean?

The levels detected do not pose an immediate risk to your health. However, some people who drink water containing TTHM in excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous systems, and may have an increased risk of getting cancer.

What is being done?

We are investigating and taking the necessary steps to correct the problem as soon as possible.

Additional information may be obtained by contacting:

Contact Person: _____.

Phone Number: _____.

Mailing Address: _____.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

PWSID: OH3500711 Facility ID: DS1 Date Distributed: _____