



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director



September 27, 2013

NOTICE OF VIOLATION – ACTION REQUIRED

Mr. Jarid P. Kohrieser
Cridersville Village Water
110 West Main Street
Cridersville, Ohio 45806

Auglaize County
Cridersville Village Water
Community PWS
PWS ID: OH0600212

Dear Mr. Kohrieser:

Cridersville Village Water is in violation of Ohio Revised Code Chapter 6109 as follows:

In violation of OAC 3745-82-02, the public water system has exceeded the secondary standard for iron which is 0.3 mg/L. There were three weeks during the month of August 2013, in which iron exceeded the secondary standard.

Monitoring and compliance determinations for the secondary maximum contaminant level for iron are as follows:

- (a) Public water systems shall use the monitoring required by OAC 3745-83-01 (F)(5) to determine compliance with the secondary maximum contaminant level for iron.
- (b) A public water system shall be in violation of the secondary standard for iron when more than 25% of the monthly samples collected at each entry point to the distribution system exceed the secondary maximum contaminant level.


Violation of the secondary standard for iron does not require public notification. Please review your operations to determine the reason for the exceedance and advise this office as to what corrections will be made.

Cridersville Village Water must take immediate action to resolve this violation. Ohio EPA may take action to enforce the requirements of its drinking water rules. A civil penalty could be assessed as part of this enforcement action.

Mr. Jarid P. Kohlrieser
September 27, 2013
Page 2

If you have any questions, please contact me at (419) 373-3007 or by e-mail at clayton.mckee@epa.ohio.gov.

Sincerely,



Clayton McKee
Division of Drinking and Ground Waters

/lr

pc: Auglaize County Health Department
DDAGW – NWDO