



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director



October 4, 2013

NOTICE OF VIOLATION – ACTION REQUIRED

Mr. Phil Critcher
Country Meadow Care Center
800 Concourse Parkway South
Suite 200
Maitland, Florida 32751

Richland County
Country Meadow Care Center
Community PWS

PWS ID: OH7003612

Dear Mr. Critcher:

REVISED LETTER

Country Meadow Care Center is in violation of Ohio Revised Code Chapter 6109 as follows:

In violation of OAC 3745-83-01(F)(5)(a)(i), the public water system failed to report iron at the plant tap on a weekly basis. There were three (3) weeks during the month in which no analysis was reported.

In violation of OAC 3745-83-01(F)(6)(a)(i), the public water system failed to report manganese at the plant tap on a weekly basis. There were three (3) weeks during the month in which no analysis was reported.

Country Meadow Care Center must take immediate action to resolve these violations. Ohio EPA may take action to enforce the requirements of its drinking water rules. A civil penalty could be assessed as part of this enforcement action. Your response to this letter is required by October 31, 2013.

If you have any questions, please contact me at (419) 373-3105 or by e-mail at curt.eldridge@epa.ohio.gov.

Sincerely,

Curtis Eldridge
Division of Drinking and Ground Waters

/llr

pc: Richland County Health Department
◀ DDAGW – NWDO ▶

