



State of Ohio Environmental Protection Agency

STREET ADDRESS:

MAILING ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 644-3020 FAX: (614) 644-3184
www.epa.state.oh.us

P.O. Box 1049
Columbus, OH 43216-1049

February 8, 2010

Mark S. Rhinehart
SRW Environmental Services, Inc.
55 West TechneCenter Drive Suite C
Milford, OH 45150

Re: Former Ironton Iron Works Class V Remediation Project – **Notice of Violation**

Dear Mr. Rhinehart:

Ohio EPA has completed its review of the February 2nd, 2010 monthly operating report providing Ohio EPA with the total volume injected in December. Pursuant to Ohio Administrative Code Rule 3745-34-11(G)(3), the injection of fluids into a class V well for purposes of remediating ground water or soil contamination is authorized without a permit if the owner submits to the director all the following information monthly while fluids are being injected:

- (a) A description of the fluids injected into the class V well;
- (b) **The volume of fluid injected into the class V well;**
- (c) **The rate of injection of fluid into the class V well; and**
- (d) Any monitoring results.

SRW Environmental is being cited in violation of the aforementioned rule as it failed to provide rates and injected volumes for each well. Any future violations may require SRW to obtain a Class V permit to operate should it intend to continue injection activities.

Should you have any questions, please contact Jess Stottsberry of my staff at (614) 644-2752.

Sincerely,

Lindsay C. Taliaferro III
UIC Manager
Division of Drinking and Ground Waters

cc: Ben Reed, DDAGW –SEDO
City of Ironton

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director