



State of Ohio Environme



## STREET ADDRESS:

Lazarus Government Center  
50 W. Town St., Suite 700  
Columbus, Ohio 43215

TELE: (614) 644-3020 FAX: (614) 644-3184  
www.epa.state.oh.us

P.O. Box 1049  
Columbus, OH 43216-1049

December 11, 2007

91 7108 2133 3931 0973 1191

Mr. Paul Beck  
President, Miami Twp Board of Trustees  
P.O. Box 98  
Cleves, Ohio 45002

Re: Class V Injection Well – Fire Station 69

Dear Mr. Beck:

This letter serves as a follow up to the correspondence between Ohio EPA and your office regarding a Class V Injection Well(s) located at 4938 East Miami River Rd, Cleves, Ohio. The October 19, 2007 letter from Ohio EPA explains that in accordance with Ohio Law, (OAC 3745-34-13)) disposal of industrial waste fluids into a Class V injection well is prohibited without first applying for and obtaining a Class V Industrial Well Permit to Operate. Industrial fluids include but are not limited to wash/rinse waters. The injection of motor vehicle wastes is strictly prohibited without exception. The inventory form you returned to Ohio EPA dated 10/29/07, indicates that Miami Township proposes to plug the floor drains at Station 69 until a plan is developed to install a holding tank.

This proposal appears it would ensure that no unauthorized fluids are injected into a Class V injection well(s), therefore Ohio EPA has no objections. Within thirty days of this notice, please provide Ohio EPA will a formal Closure Plan that will need to include a date for closure. In the meantime, no injection through the floor drains is authorized.

Should you have any questions, please call me at (614) 644-2752.

Sincerely,

Jess Stottsberry  
UIC Unit Geologist  
Division of Drinking and Ground Waters

cc: Lindsay Taliaferro III, UIC Manager, DDAGW

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director