


**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director



September 23, 2011

Martha Connell
Parker-Hannifin Corp.
6035 Parkland Blvd
Cleveland, OH 44124-4141

Re: NOTICE OF VIOLATION – Parker-Hannifin, Waverly, Ohio EPA

Dear Ms. Connell:

Ohio EPA's Underground Injection Control (UIC) Unit has recently become aware that the Parker Hannifin site in Waverly, Ohio is actively injecting air into Class V UIC wells for the purpose of remediating soil and ground water contamination at the subject site. In April of 2003, Parker-Hannifin submitted a work plan to Ohio EPA UIC in order to be exempted from the formal permitting requirements to use Class V remediation wells. Its Ohio EPA UIC's understanding that thirteen (13) Class V wells would be installed to inject ambient air into the subsurface. In addition, Parker-Hannifin had obtained authorization to discharge contaminated water taken from an extraction well, which would be sent through an air stripper and discharged via a NPDES permit.

According to Ohio EPA UIC files, no recent monthly operating reports have been provided as required by Ohio Administrative Code Rule 3745-34-11(H)(3). Therefore, it was assumed that the injection wells were either closed or inactive. After discussion with our district staff, it was determined that these wells are in fact active and Parker-Hannifin has failed to report the monthly injection activity to Ohio EPA UIC. In order to return to compliance, Parker-Hannifin must immediately begin submitting monthly operating reports to Ohio EPA UIC, to the return address at the bottom center of this page. Failure to do so may nullify Parker-Hannifin's authorization to operate Class V UIC wells without a permit to operate per OAC Rule 3745-34-11(H).

Page 2

If you have any questions, please contact Jess Stottsberry of my staff at (614) 644 -2752 or via email at jess.stottsberry@epa.state.oh.us .

Sincerely,



Lindsay C. Taliaferro III
UIC Program Manager
Division of Drinking and Ground Waters

cc: Michael Eggert, Assistant Chief, DDAGW
Steve Williams, Ground Water Supervisor, SEDO
Steve Saines, SEDO