



State of Ohio Environr



STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 644-3020 FAX: (614) 644-3184
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

December 12, 2007

Ronald Czarnecki
Service Master
8600 Harrison Pike
Cincinnati, OH 45248

91 7108 2133 3931 0973 1160

Re: Class V Injection Well – Service Master

Dear Mr. Czarnecki:

This letter serves as a follow up to the correspondence between Ohio EPA and your office regarding the existence of Class V Injection wells at your business located at 8600 Harrison Pike, Cincinnati, Ohio. The September 21, 2007 letter from Ohio EPA explains that in accordance with Ohio Law, (OAC 3745-34-13) disposal of motor vehicle waste fluids into a Class V well is strictly prohibited. The telephone conversation and inventory form you returned and dated 10/10/07, indicates that your business does not do any type of repair work that would allow a discharge of motor vehicle waste fluids. However, you had indicated that the septic system does receive fluids associated with your carpet cleaning equipment/business.

Ohio Administrative Code (OAC) Rule 3745-34-01(LL) defines Industrial Waste as: any liquid, gaseous, or solid waste substance resulting from any process of industry, manufacture, trade, or business, or from the development, processing, or recovery of any natural resource, together with such sewage as is present to an on lot disposal system such as a septic tank, dry well or leach field.

Therefore, based on the information provided, your business discharges industrial waste. The disposal of industrial waste fluids into a Class V injection well is prohibited without first applying for and obtaining a Class V Industrial Well Permit to Operate. The inventory form you submitted, did indicate that your intentions were to apply for and obtain a permit to install a holding tank for your industrial fluids. The installation of an Ohio EPA permitted holding tank, would ensure your compliance with applicable underground injection control (UIC) rules and regulations.

Within thirty days of receipt of this notice, Ohio EPA requests a formal Closure Plan that will include a detailed timeline for the closure of your Class V injection well. In the meantime, absolutely no injection through floor drains leading to the

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Page 2

septic system is authorized. Should you wish to apply for a UIC Permit To Operate instead of installing a holding tank, a permit application will be provided upon request. All permit applications include a \$2,000.00 application fee.

Should you have any questions, please call me at (614) 644-2752.

Sincerely,

A handwritten signature in black ink, appearing to read 'J. Stottsberry', written over a horizontal line.

Jess Stottsberry
UIC Unit Geologist
Division of Drinking and Ground Waters

cc: Lindsay Taliaferro III, UIC Manager, DDAGW