



**Environmental  
Protection Agency**

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director



November 17, 2011

**NOTICE OF VIOLATION – ACTION REQUIRED**

CERTIFIED MAIL

91 7108 2133 3937 1501 4015

Jeremy Carico  
Liberty Center Village  
110 East Street, Po Box 92  
Liberty Center, OH 43532

Henry County  
Liberty Center Village  
Community PWS  
PWS ID: OH3500603

**Subject: Violation of Maximum Contaminant Level for TOTAL TRIHALOMETHANES (TTHM)**

Liberty Center Village is in violation for exceeding the maximum contaminant level (MCL) standard of 0.080 MG/L as established in the Ohio Administrative Code (OAC) section 3745-81-12 for TTHM. Compliance with the MCL is based on a running annual average. The annual average for TTHM during the Third Quarter of 2011 time period is 0.083 MG/L.

To address the MCL violation, Liberty Center Village is required to take the following actions:

1. Notify your customers within 30 days using the enclosed instructions and public notice.
2. Complete and send a verification form with a copy of the public notice to the mailing address below within ten days after issuance.
3. Perform quarterly monitoring for TTHM during each calendar quarter (January 1 – March 31; April 1 – June 30; July 1 – September 30; October 1 to December 31).
4. Consult with your Ohio EPA district representative to discuss your options for coming into compliance and establishing a compliance schedule or comply with any previously issued enforcement action.

Your prompt attention to this matter is greatly appreciated. Continued noncompliance may lead to additional enforcement actions. If you have any questions or wish to change the public notice, please call me at (614) 644-2752.

Sincerely,

Sarah Byerly  
Compliance Assurance Section  
Division of Drinking and Ground Waters

Enclosure: Public Notice; Public Notice Instructions and Verification Form  
cc: Manager; DDAGW file; NWDO file; Henry County Health Department

50 West Town Street, Suite 700  
P.O. Box 1049  
Columbus, OH 43216-1049

614 | 644 3020  
614 | 644 3184 (fax)  
www.epa.ohio.gov

# DRINKING WATER NOTICE

## Liberty Center Village Has Levels of TOTAL TRIHALOMETHANES (TTHM) above Drinking Water Standards

Our water system recently violated the maximum contaminant level (MCL) for TTHM. The average level of TTHM over the last four quarters was 0.083 MG/L. The standard for TTHM is 0.080 MG/L.

### What should I do?

- **You do not need to use an alternative (e.g., bottled) water supply.** However, if you have specific health concerns, consult your doctor.

### What does this mean?

The levels detected do not pose an immediate risk to your health. However, some people who drink water containing trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous systems, and may have an increased risk of getting cancer.

### What is being done?

We are investigating and taking the necessary steps to correct the problem as soon as possible.

Additional information may be obtained by contacting:

Contact Person: \_\_\_\_\_

Phone Number: \_\_\_\_\_

Mailing Address: \_\_\_\_\_

*Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.*

Date Distributed: \_\_\_\_\_

PWSID: OH3500603

Monitoring Period: Third Quarter of 2011