



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

October 8, 2013



NOTICE OF VIOLATION – ACTION REQUIRED

Mr. John P. Applegate
118 North Main Street
Union, Ohio 45322

RE: **Montgomery County
Union City
Community PWS
PWS ID: OH5702512**

Dear Mr. Applegate:

Union City is in violation of Ohio Revised Code Chapter 6109 as follows:

Failure to maintain fluoride between 0.8 – 1.3 mg/L at the plant tap: 4 days or more

In violation of OAC 3745-82-03(C)(1)(c), the City of Union failed to maintain fluoride between 0.8 – 1.3 mg/L at the plant tap for four or more days during the month. Specifically, there were twelve (12) days in the month of August, 2013 in which fluoride was outside this range. No public notice is required for this violation. Please review your operations to determine the reason for the variability of the fluoride feed and advise this office as to what corrections will be made.

Union City must take immediate action to resolve this violation. Ohio EPA may take action to enforce the requirement of its drinking water rules. A civil penalty could be assessed as part of this enforcement action. Your response to this letter is required by within thirty (30) days from the date of this letter.

If you have any questions, please contact me at (937) 285-6117.

Sincerely,

John McDaniel
Environmental Specialist II
Division of Drinking and Ground Waters

JM/tb

ec: Montgomery County Health Department