



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director



October 3, 2013

RE: WAYNE COUNTY
MCDONALD'S RESTAURANT - WOOSTER
NON-TRANSIENT, NON-COMMUNITY
PUBLIC WATER SYSTEM
PWS ID # OH8553912 / STU ID# 8559762

Chuck Schafrath, Operations Supervisor
McDonald's Restaurant
2130 E. Lincoln Way
Wooster, Ohio 44691

Dear Mr. Schafrath:

On September 9, 2013, this office received the August 2013 Monthly Operating Report (MOR form 5002) from McDonald's Restaurant - Wooster. Operational monitoring is conducted throughout the month to test the treatment effectiveness of the water plant. Since McDonald's Restaurant - Wooster treats its water by softening (hardness removal) and chlorine injection (disinfection), you are required to conduct monitoring for chlorine residual.

Please note the following violations:

- **Failure to report chlorine residual (free or combined) daily at the (plant tap and/or distribution system); 3 days or more - NOV 3745-83-01 (F)(2)**

In violation of OAC 3745-83-01 (F)(2), the public water system failed to report chlorine residuals daily. There were 8 days during the month of June 2013 in which the analysis was not performed and/or recorded. Please ensure monitoring and recording of the residuals is conducted each day.


- **Failure to maintain the minimum required (free or combined) chlorine residual in the distribution system; 3 days or more - NOV 3745-83-01 (C)(1)**

In violation of OAC 3745-83-01 (C)(1), the public water system failed to maintain the minimum required (free/combined) chlorine residual in the distribution system when the residual disinfectant concentration of the drinking water at representative points throughout the distribution systems was less than (two-tenths milligram per liter free chlorine / one milligram per liter combined chlorine). There were 6 days during the month in which the minimum chlorine residual was not maintained.

MCDONALD'S RESTAURANT – WOOSTER
OCTOBER 3, 2013
PAGE 2

If you have any questions regarding this correspondence, or if you need any assistance, please contact me at (330) 963-1194 or at my e-mail address, beth.madis@epa.ohio.gov.

Sincerely,

A handwritten signature in cursive script that reads "Beth R Madis".

Beth R. Madis
Environmental Specialist
Division of Drinking and Ground Waters

BRM/ams

cc: Wayne County Health Department
Ohio EPA, Central Office, DDAGW
Kim Ethers, Ohio EPA, Central Office, DDAGW
Brock McGhee, McGhee's Technical Water Service