Ohio EPA
40 years and moving forward

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

October 7, 2013

RE: **NOTICE OF VIOLATION**
HOLMES COUNTY
INN AT HONEY RUN
NTNC WATER SYSTEM
PWS ID # OH3843912

Mr. Ed Van Natta
Inn at Honey Run
6920 County Road 203
Millersburg, OH 44654

Dear Mr. Van Natta:

This letter is notification that the Inn at Honey Run public water system is in violation of Ohio Administrative Code (OAC) Rule 3745-83-01(F) which states that a public water system that provides water treated with chlorine shall monitor for free or combined chlorine at least once every day that water is available to the public at each entry point to the distribution system and a representative point or points in the distribution system. A non-community ground water system whose distribution system is solely interior plumbing in a single building, only needs to collect one representative sample daily.

This violation of the OAC is based upon information submitted by the Inn at Honey Run PWS as reported on Monthly Operating Report (MOR) #5002 for August 2013. Results reported on the form indicated 22 days where no result was reported.

An evaluation/investigation should be conducted to determine why no result was collected and what corrective action is necessary. Please provide your findings to this writer within 30 days from the date of this letter.

If you have any questions, please contact me directly at (330) 963-1248.

Respectfully,

J. Robert Henn
Environmental Specialist
Division of Drinking and Ground Waters

JRH/ams

cc: Kim Etters, Ohio EPA, NEDO, DDAGW
Mr. David Schlabach, Operator of Record