



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director



October 11, 2013

Mr. Rob Schuman
Waldo Sports Bar and Grill
306 South Main Street
Waldo, Ohio 43356

Marion County
Waldo Sports Bar and Grill
Non-Community, Transient PWS
PWS ID: OH5137012
VIO ID: 9719417

Subject: Rescinding Violation – TCR

Your public water system was issued a notice of violation of Rule 3745-81-21 of the Ohio Administrative Code (OAC), dated September 25, 2013 the monitoring period of August 2013. The samples were all collected on August 27, 2013 but not all the results were reported to our office until September 30, 2013.

The violation has been rescinded and the public notice sent with the notice of violation referenced above does not need to be issued at this time.

OAC 3745-81-31 and 3745-89-08 require results to be reported by the tenth day following the month the sample was collected. Further, OAC 3745-89-08 requires the laboratory to report all positive, all repeat sample results and all samples required by OAC 3745-81-42 (Ground Water Rule) no later than the end of the next business day after the result was obtained. The sample(s) was (were) not reported in accordance with the above rules and this is considered a reporting violation.

Please ensure future sample results are submitted as required. If you have any questions, please contact me at 419-373-3108 or by e-mail at janis.damico@epa.ohio.gov.

Sincerely,

Janis D'Amico
Division of Drinking and Ground Waters

/cg

pc: Marion County Health Department
Alloway – Marion Laboratory
DDAGW - NWDO

