



Environmental  
Protection Agency

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

December 7, 2011

Mr. Jack Thacker  
Century 21 Thacker & Associates, Inc.  
3996 Oxford Millville Road  
Oxford, Ohio 45056

Re: Hamilton County, Century 21 Thacker & Associates, Inc.  
NPDES Permit Violations

Dear Mr. Thacker:

On June 1, 2011, the General NPDES Permit for Small Sanitary Dischargers (NPDES Permit # OHGV00086; OEPA Permit # 1GV00007\*AG) became effective for your facility. The permit requires that your WWTP discharge be monitored each September. The results are to be reported on the Discharge Monitoring Reports. These requirements are addressed in Part III, Section 1 of your permit. At this time, you have failed to monitor and report these results.

In addition, a Permit to Install for upgrading your WWTP was required to be submitted on December 1, 2011. At this time, you have failed to submit this application.

Please be advised that failure to comply with the compliance schedule or to satisfy the monitoring or reporting requirements of your NPDES Permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

Please inform this office, in writing, by December 30, 2011 as to the reasons for the above referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions. Future violations must be reported as required by the NPDES Permit as detailed in Part III.12 titled "Noncompliance Notification."

If you have any questions regarding the above, please contact me at (937) 285-6096.

Sincerely,

Ned Sarle  
Division of Surface Water  
Permit Section