



**Environmental  
Protection Agency**

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

November 21, 2011

Jim Leslie  
City of Harrison WWTP  
10999 Campbell Road  
Harrison, Ohio 45030

RE: Notice of Violation  
Harrison WWTP  
NPDES Permit 1PC00002\*ID/OH0021440

Dear Mr. Leslie:

We have received your self-monitoring report for the month of October 2011, for the City of Harrison's Wastewater Treatment Plant. Our review indicates violations of the conditions of the NPDES permit for the facility. The specific instances of noncompliance are as follows:

**EFFLUENT LIMIT VIOLATIONS AT OUTFALL 001**

Parameter	Limit Type	Limit	Reported Value	Violation Date
Total Suspended Solids	7D Conc	18	18.3333	10/1/2011
Nitrogen, Ammonia	30D Conc	1.0	1.29167	10/1/2011
Nitrogen, Ammonia	7D Conc	1.5	1.90333	10/1/2011
Nitrogen, Ammonia	7D Conc	1.5	2.63333	10/8/2011

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

I have reviewed your noncompliance notification letter that was received in this office on October 12, 2011. Violations of the Nitrogen Ammonia limit have become chronic at this facility. A response is required to this notice of violation detailing additional steps that will be taken by the Operators of Record to ensure compliance with the effluent

Jim Leslie  
November 21, 2011  
Page 2

limits. Please submit your response by December 9, 2011. If you have any questions regarding this Notice of Violation letter, please call me at (937) 285-6101.

Sincerely,

A handwritten signature in cursive script, appearing to read "Mary Osika".

Mary Osika  
Environmental Specialist  
Division of Surface Water

cc: Joel McGuire, City of Harrison  
Bill Fischbein, Ohio EPA-Legal