Ohio | Environmental Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

December 29, 2011

Village of Greenfield
Attn: Ms. Betty Bishop,
300 Jefferson Street
Greenfield, OH 45123

Re: Greenfield WWTP- 1PD00022*HD
Notice of Violation

Dear Ms. Bishop:

A compliance review was conducted on your Discharge Monitoring Report (DMR) submitted on December 14, 2011. As detailed at the end of this letter, screening of your submitted DMR has identified compliance issues.

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES Permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

We have reviewed your report addressing the reasons for the above violations and the actions being taken to prevent further occurrences. No additional information is requested at this time. Future violations must continue to be reported as required by the NPDES Permit as detailed in Part III.12 titled "Non-compliance Notification".

If you should have any questions, feel free to contact me by phone at (937) 285-6029 or by electronic mail at Joshua.Jackson@epa.state.oh.us.

Respectfully,

Joshua Jackson
Environmental Specialist II
Division of Surface Water

Ec: Jim McCoy, Village of Greenfield (greenfield_wwtp@frontier.com)

Southwest District Office
401 East Fifth Street
Dayton, OH 45402-2911

937 | 285 6357
937 | 285 6249 (fax)
www.epa.ohio.gov

Ohio | Environmental Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

Notice of Violation Report

Facility: Greenfield WWTP

Permit No.: 1PD00022*HD

Report Period: November 2011 **Date Received:** 12/14/2011

Station	Type	Date	Reporting Code	Parameter	Limit Type	Permit Limit	Reported Value
001	Limit	11/22/2011	00300	Dissolved Oxygen	Daily Conc.	6.0	5.9