



Environmental  
Protection Agency

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

November 29, 2011

Steve Mascho  
Fairlawn Local School District  
188800 Johnston Road  
Sidney, OH 45365

**CERTIFIED LETTER**

**RE: Fairlawn High School, Shelby County  
Self-Monitoring Report Notice of Violation – January through October 2011  
NPDES No. 1PT00103/OH0131962**

Dear Mr. Mascho:

We have received your self-monitoring reports for Fairlawn High School. Our review indicates violations of the conditions of your NPDES permit. Ohio EPA considers this wastewater treatment plant to be in significant noncompliance. The specific instances of noncompliance and deficiencies for this facility are attached to this letter.

We have received your reports addressing the reasons for the above violations and the actions being taken to prevent further occurrences. Your explanation is not satisfactory and we request, no later than December 16, 2011, written information as to what additional steps you will take to prevent further occurrences. Your response should include, but not limited to the following: operational and maintenance changes, implementation of process control measures, any needed upgrades on infrastructure, removal of inflow and infiltration if needed and a description of any other abatement options required to resolve noncompliance issues. Your response must define the conditions contributing to the significant violations and must include a fixed schedule (month, date and year) along with specific actions to return to compliance.

Please be advised that Ohio EPA Southwest District Office will recommend enforcement action against Fairlawn High School if action is not taken to abate significant violations.

If you have any questions regarding the above, please contact me at (937) 285-6104.

Respectfully,

Sandra D. Leibfritz  
Division of Surface Water

cc: [kent.topp@odh.ohio.gov](mailto:kent.topp@odh.ohio.gov)  
[dfreisthler@woh.rr.com](mailto:dfreisthler@woh.rr.com)

**Fairlawn High School  
January through October 2011**

<b>Reporting Period</b>	<b>Parameter</b>	<b>Limit Type</b>	<b>Limit</b>	<b>Reported Value</b>	<b>Violation Date</b>
January 2011	Nitrogen, Ammonia (NH3)	30D Conc	3.0	80.45	1/1/2011
January 2011	Nitrogen, Ammonia (NH3)	30D Qty	0.11	.91351	1/1/2011
February 2011	Nitrogen, Ammonia (NH3)	30D Conc	3.0	24.61	2/1/2011
February 2011	Nitrogen, Ammonia (NH3)	7D Conc	4.5	24.61	2/15/2011
June 2011	Total Suspended Solids	30D Conc	12	17.	6/1/2011
June 2011	Chlorine, Total Residual	1D Conc	0.038	.09	6/7/2011
July 2011	Chlorine, Total Residual	1D Conc	0.038	.08	7/20/2011
September 2011	Total Suspended Solids	30D Conc	12	16.	9/1/2011
October 2011	Total Suspended Solids	30D Conc	12	33.	10/1/2011
October 2011	Total Suspended Solids	30D Qty	0.45	.49962	10/1/2011
October 2011	Nitrogen, Ammonia (NH3)	30D Conc	1.0	5.53	10/1/2011
October 2011	Nitrogen, Ammonia (NH3)	30D Qty	0.04	.08372	10/1/2011
October 2011	Fecal Coliform	30D Conc	1000	2419.6	10/1/2011
October 2011	CBOD 5 day	30D Conc	10	14.66	10/1/2011
October 2011	Total Suspended Solids	7D Conc	18	33.	10/15/2011
October 2011	Nitrogen, Ammonia (NH3)	7D Conc	1.5	5.53	10/15/2011
October 2011	Nitrogen, Ammonia (NH3)	7D Qty	0.06	.08372	10/15/2011
October 2011	Fecal Coliform	7D Conc	2000	2419.6	10/15/2011