Ohio | Environmental Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

December 14, 2011

Amy and James Childress
8294 Jordan Ridge
Cleves, Ohio 45002

RE: Edgewater Mobile Home Park
NPDES Permit 1PV00120*BD
NOTICE OF VIOLATION

Dear Mr. and Mrs. Childress:

Ohio EPA has received the discharge monitoring report for your sewage treatment plant for September 2011. A compliance review indicates violations of the conditions of the NPDES permit for this facility. The specific instances of non-compliance are as follows:

SEPTEMBER 2011 – MONITORING FREQUENCY VIOLATIONS AT OUTFALL 001

Parameter	Required Sampling Frequency	Data reported
Temperature	1/week	0
Dissolved Oxygen	1/week	0
pH	1 per 2 weeks	0
Suspended Solids	1/month	0
Ammonia, Nitrogen	1/month	0
Fecal Coliform	1/month	0
CBOD5	1/month	0
Flow Rate	Daily	0
Color Odor Turbidity	Daily	1

Ohio EPA has not received the discharge monitoring report for October 2011. This is considered a violation of the monitoring and reporting conditions of your NPDES Permit. Ohio EPA is aware that your contract operator removed himself from this sewage treatment plant due to non-payment. Failure to have a class I certified operator is a violation of the conditions of your NPDES permit.

Ohio EPA has been notified by the Hamilton County Public Health that the operation and maintenance of the sewage treatment plant has deteriorated and is not providing adequate treatment. An inspection by their department on December 6 detailed the treatment units in disrepair and other problems seen at the sewage treatment plant.

Southwest District Office
401 East Fifth Street
Dayton, OH 45402-2911

937 | 285 6357
937 | 285 6249 (fax)
www.epa.ohio.gov

You are required to respond to this Notice of Violation within 10 days or by December 28, 2011 detailing the actions you are taking to repair the sewage treatment plant and obtain an operator to take your samples. You may contact me at (937) 285-6101 if you have any questions about this letter.

Sincerely,

Mary Osika
Environmental Specialist
Division of Surface Water

ec: Jeremy Hessel, Hamilton County Public Health
Rob Gallenstein, Hamilton County Public Health