



**Environmental Protection Agency**

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

RE: Crawford County  
Spring Valley Mobile Home Park  
NPDES Permit

December 29, 2011

Mr. Jay Wagner, Owner  
118 Harding Way West  
P.O. Box 576  
Galion, Ohio 44833

Dear Mr. Wagner:

On December 12, 2011, an inspection was made of the wastewater treatment facilities serving the Spring Valley Mobile Home Park, located at 5913 Spring Valley Court, Galion, Ohio. General operation of the plant appears to be good and our findings and recommendations are below.

At the time of the inspection, the plant blowers were not on; therefore, the air to the aeration tank, the sludge return, and the skimmer were not evaluated. The flow from the clarifier was clear. The sand filters were in good condition. The effluent at the discharge point appeared to be clear.

A review of your discharge monitoring reports from January 2011 through November 2011 indicates two violations of the conditions set forth in your permit. These violations are listed below.

Violation Date	Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value
6/1/2011	001	00530	Total Suspended Solids	30D Conc	12.0	20.
6/1/2011	001	00530	Total Suspended Solids	7D Conc	18.0	20.

If you have further questions, please call me at (419) 373 -3019.

Sincerely,

Michelle Sharp  
Environmental Specialist II  
Division of Surface Water

/jlm

pc: Crawford County Health Department  
Mr. Lonnie McGhee, McGhee Technical Water Services,  
ec: Inspection Tracking