



**Environmental
Protection Agency**

John R. Kasich, Governor

Mary Taylor, Lt. Governor

Scott J. Nally, Director

December 22, 2011

RE: AKRON CANTON REGIONAL AIRPORT
PERMIT NO. 3GC05432*AG
SUMMIT COUNTY
STORM WATER

Richard McQueen
Akron Canton Regional Airport
5400 Lauby Road NW #9
North Canton, Ohio 44720

Dear Mr. McQueen:

On December 21, 2011, this writer conducted an inspection of the Akron Canton (ARFF) Snow/Ice Control construction site located north of Mt. Pleasant Road. There was no construction trailer on-site and there were no personnel present. The purpose of the inspection was to determine compliance with Ohio EPA General Storm Water National Pollutant Discharge Elimination System (NPDES) Permit for Construction Activities No. 3GC05432*AG. Our records indicate that the Akron Canton Regional Airport was granted coverage under the NPDES permit on April 29, 2011. The indicated acreage on the application is 11.93 acres. At the time of the inspection the following was noted:

- 1) A significant percentage, if not all, of the site has been disturbed.
- 2) The only storm water controls present were silt fences.
- 3) Silt fence is being used on the south side of the site to control a major portion of storm water leaving the site. This is an inappropriate use of silt fence.
- 4) There is no sedimentation basin installed to control runoff.
- 5) The Storm Water Pollution Prevention Plan (SWPPP) was not on-site for review. This is a violation of your permit.

Pictures of the site taken during the inspection are attached for your reference.

You are requested to submit a copy of the SWPPP and any related accompanying detail plans to this office for our review no later than January 4, 2012. If site controls have not been installed according to the approved SWPPP, then construction should stop until the required controls have been installed.

If you should have any questions concerning the above, feel free to contact this writer at (330) 963-1136 or by e-mail at phil.rhodes@epa.state.oh.us.

Sincerely,



Philip P. Rhodes, P.E.
Environmental Specialist II
Division of Surface Water

PR/cs

CC: Brian Prunty, Summit Soil and Water Conservation District

File: Construction Storm water/Summit County/City of Green



