Ohio Environmental Protection Agency
John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

December 1, 2011

RE: ASHTABULA COUNTY
CITY OF ASHTABULA
NORTHGATE CENTER
NPDES PERMIT NO. OHC000003
OHIO EPA PERMIT NO. 3GC05715*AG
CONSTRUCTION STORM WATER

Ronald Kister
NEO Development
P.O. Box 768
Ashtabula, OH 44004

Dear Mr. Kister:

On November 3, 2011, Ohio EPA conducted an inspection of Northgate Center, located at 1200 Lake Avenue, City of Ashtabula, Ashtabula County (site). Ohio EPA records indicate that the site is covered by General National Pollutant Discharge Elimination System Permit for Storm Water Associated with Construction Activity (General Storm Water Permit), permit No. 3GC05715*AG. The inspection documented the following:

Site Inspection

The inspection documented the following violations occurring on the site that must be addressed via appropriate best management practices (BMP):

- The northeastern portion of the site appears to be idle and must be stabilized with seed and mulch to prevent erosion and the discharge of sediment during precipitation events.

Within 10 days of receiving this inspection letter, written correspondence detailing the corrective action(s) that have been implemented and/or will be implemented at the site must be submitted to Ohio EPA. Should you have any questions regarding this matter, please contact me at your earliest convenience at (330) 963-1118 or via e-mail chris.moody@epa.ohio.gov.

Sincerely,

Chris Moody
Environmental Specialist II
Division of Surface Water

CM/cs

Cc: Michael Mearni, Superintendent

Northeast District Office
2110 East Aurora Road
Twinsburg, OH 44087-1924

330 | 963 1200
330 | 487 0769 (fax)
www.epa.ohio.gov