

**Environmental
Protection Agency**

— Governor
— Lt. Governor
— Director



December 8, 2011

RE: TRUMBULL COUNTY
GREENE TOWNSHIP
MAPLEWOOD ELEMENTARY SCHOOL
COMPLIANCE EVALUATION INSPECTION
(NPDES PERMIT 3PT00071)

Maplewood Local School District
Attn: Perry D. Nicholas, Superintendent
2414 Greenville Road N.E.
Cortland, OH 44410

Dear Mr. Nicholas:

On November 9, 2011, a compliance evaluation inspection (CEI) was conducted on the wastewater treatment plant (WWTP) serving the Maplewood Elementary School. The facility is located at 1699 Kinsman Road, in Greene Township, Trumbull County. Present for the inspection were Mr. John Brown, representing the school system, and this writer.

The purpose of the inspection was to evaluate the Operation and Maintenance of the WWTP, and to evaluate compliance with the National Pollutant Discharge Elimination System (NPDES) permit effluent limits. The previous CEI was conducted on January 8, 2009.

At the time of the November 9 inspection, the following observations were made and information was obtained:

- 1) The trash trap was in use and its contents were typical. The trash trap is usually pumped twice per year, in September and February.
- 2) The flow equalization tank was in use and was being aerated. Air to the flow equalization tank is supplied by up to three blowers, and blower operation is continuous (i.e. not on a timer). Blowers #1 and #3 were operating, while blower #2 was in standby mode. The flow equalization pumps were operating properly.
- 3) Extended aeration tank contents were grayish brown and well aerated, with no foam present. The return activated sludge (RAS) line was returning light brown liquid from the settling tank to the aeration tank. Since the last inspection, the air diffusers have been replaced, and new belts have been installed on the blower motors.

- 4) The settling tank contents were slightly turbid, and there was a slight buildup of solids behind the inlet baffle. The skimmer was operational, returning clear water to the aeration tank. The settling tank effluent trough contained some solids and was in need of leveling. The skimmer pipe was properly adjusted.
- 5) Both sand filter dosing pumps were set in the 'AUTO' mode, and operated when manually tested. The high level alarm was also operational when manually tested. Pump totalizing recorders in the dosing station are used to estimate daily flow for the WWTP.
- 6) The south surface sand filter cell was in use and was flooded with water. The north filter cell contained some leaves and dead vegetation. Since the last inspection, splash pads in both of the filter cells have been repaired to provide proper support for the dosing pipes.
- 7) Treated effluent is disinfected by tablet chlorination and dechlorination units during the disinfection season. At the time of the inspection, the chlorination/dechlorination units contained no tablets, as disinfection is not required for the period of November 1 through April 30. All tubes were present in the two tube units, and they were properly capped.
- 8) The aerated sludge holding tank contents were well aerated and light brown in color. When needed, A-1 Drain service hauls the liquid sludge to a larger WWTP for disposal.
- 9) Effluent being discharged from the WWTP was clear and visually free of solids.
- 10) Mr. Brown collects the WWTP effluent samples, and transports them to Cardinal Labs for analysis. The sample bottles are prepared by, and given to Mr. Brown, by Cardinal Labs.
- 11) The licensed responsible operator in charge of the Maplewood Elementary School WWTP is Mr. Scott Mascioli. Mr. Mascioli conducts the dissolved oxygen and pH testing onsite at the WWTP. The eDMR data is submitted to the Ohio EPA and pinned by Mr. Mascioli.

A review of the electronic Discharge Monitoring Reports (eDMR), as reported to the Ohio EPA for the Maplewood Elementary School WWTP during the period of December 1, 2008 through November 1, 2011, found the following numeric effluent violations for the facility:

MAPLEWOOD LOCAL SCHOOL DISTRICT
 DECEMBER 8, 2011
 PAGE 3

MAPLEWOOD ELEMENTARY SCHOOL
NUMERIC EFFLUENT VIOLATIONS
NPDES PERMIT NO. 3PT00071
(DEC. 1, 2008 – NOV. 1, 2011)

| Reporting Period | Parameter | Limit Type | Limit | Reported Value | Violation Date |
|------------------|---------------------------|------------|-------|----------------|----------------|
| December 2008 | Nitrogen, Ammonia (NH3-N) | 30D Conc | 3.0 | 46.6 | 12/1/2008 |
| December 2008 | Total Suspended Solids | 30D Conc | 12 | 30.8 | 12/1/2008 |
| December 2008 | Nitrogen, Ammonia (NH3-N) | 30D Qty | 0.06 | .28574 | 12/1/2008 |
| December 2008 | Nitrogen, Ammonia (NH3-N) | 7D Qty | 0.09 | .28574 | 12/8/2008 |
| December 2008 | Nitrogen, Ammonia (NH3-N) | 7D Conc | 4.5 | 46.6 | 12/8/2008 |
| December 2008 | Total Suspended Solids | 7D Conc | 18 | 30.8 | 12/8/2008 |
| March 2009 | Nitrogen, Ammonia (NH3-N) | 30D Conc | 3.0 | 9.1 | 3/1/2009 |
| March 2009 | CBOD 5 day | 30D Conc | 10 | 10.58 | 3/1/2009 |
| March 2009 | Nitrogen, Ammonia (NH3-N) | 7D Conc | 4.5 | 9.1 | 3/22/2009 |
| June 2009 | Fecal Coliform | 30D Conc | 1000 | 2200. | 6/1/2009 |
| June 2009 | Fecal Coliform | 7D Conc | 2000 | 2200. | 6/15/2009 |
| June 2009 | Dissolved Oxygen | 1D Conc | 6.0 | 5.84 | 6/23/2009 |
| August 2009 | Total Suspended Solids | 30D Conc | 12 | 24.7 | 8/1/2009 |
| August 2009 | Total Suspended Solids | 7D Conc | 18 | 24.7 | 8/15/2009 |
| December 2009 | Nitrogen, Ammonia (NH3-N) | 30D Conc | 3.0 | 10.9 | 12/1/2009 |
| December 2009 | Total Suspended Solids | 30D Conc | 12 | 36. | 12/1/2009 |
| December 2009 | Total Suspended Solids | 7D Conc | 18 | 36. | 12/8/2009 |
| December 2009 | pH | 1D Conc | 6.5 | 5.9 | 12/8/2009 |
| December 2009 | Nitrogen, Ammonia (NH3-N) | 7D Conc | 4.5 | 10.9 | 12/8/2009 |
| March 2010 | Nitrogen, Ammonia (NH3-N) | 30D Conc | 3.0 | 10.8 | 3/1/2010 |
| March 2010 | Total Suspended Solids | 30D Conc | 12 | 38.4 | 3/1/2010 |
| March 2010 | Nitrogen, Ammonia (NH3-N) | 7D Conc | 4.5 | 10.8 | 3/8/2010 |
| March 2010 | Total Suspended Solids | 7D Conc | 18 | 38.4 | 3/8/2010 |
| March 2010 | Dissolved Oxygen | 1D Conc | 6.0 | 3.33 | 3/12/2010 |
| December 2010 | Nitrogen, Ammonia (NH3-N) | 30D Conc | 3.0 | 3.88 | 12/1/2010 |
| December 2010 | Total Suspended Solids | 30D Conc | 12 | 26. | 12/1/2010 |
| December 2010 | Total Suspended Solids | 7D Conc | 18 | 26. | 12/8/2010 |
| December 2010 | pH | 1D Conc | 6.5 | 6.17 | 12/9/2010 |
| March 2011 | Nitrogen, Ammonia (NH3-N) | 30D Conc | 3.0 | 4.1 | 3/1/2011 |
| June 2011 | Total Suspended Solids | 30D Conc | 12 | 15. | 6/1/2011 |
| June 2011 | Nitrogen, Ammonia (NH3-N) | 30D Conc | 1.0 | 4.31 | 6/1/2011 |
| June 2011 | Nitrogen, Ammonia (NH3-N) | 7D Conc | 1.5 | 4.31 | 6/8/2011 |
| August 2011 | Total Suspended Solids | 30D Conc | 12 | 25. | 8/1/2011 |
| August 2011 | Total Suspended Solids | 7D Conc | 18 | 25. | 8/8/2011 |

MAPLEWOOD LOCAL SCHOOL DISTRICT
 DECEMBER 8, 2011
 PAGE 4

A review of the eDMRs for the same period also found the following reporting frequency violations for the Maplewood Elementary School:

**MAPLEWOOD ELEMENTARY SCHOOL
 REPORTING FREQUENCY VIOLATIONS
 NPDES PERMIT NO. 3PT00071
 (DEC. 1, 2008 – NOV. 1, 2011)**

| Reporting Period | Reporting Code | Parameter | Sample Frequency | Expected | Reported | Violation Date |
|------------------|----------------|--------------------------|------------------|----------|----------|----------------|
| December 2008 | 31616 | Fecal Coliform | 1/Quarter | 1 | 0 | 12/01/2008 |
| December 2008 | 50060 | Chlorine, Total Residual | 1/Quarter | 1 | 0 | 12/01/2008 |
| December 2009 | 31616 | Fecal Coliform | 1/Quarter | 1 | 0 | 12/01/2009 |
| December 2009 | 50060 | Chlorine, Total Residual | 1/Quarter | 1 | 0 | 12/01/2009 |
| December 2010 | 50060 | Chlorine, Total Residual | 1/Quarter | 1 | 0 | 12/01/2010 |
| December 2010 | 31616 | Fecal Coliform | 1/Quarter | 1 | 0 | 12/01/2010 |
| June 2009 | 01350 | Turbidity, Severity | 1/Week | 1 | 0 | 06/15/2009 |
| June 2009 | 00083 | Color, Severity | 1/Week | 1 | 0 | 06/15/2009 |
| June 2009 | 01330 | Odor, Severity | 1/Week | 1 | 0 | 06/15/2009 |
| June 2009 | 00083 | Color, Severity | 1/Week | 1 | 0 | 06/08/2009 |
| June 2009 | 01350 | Turbidity, Severity | 1/Week | 1 | 0 | 06/08/2009 |
| June 2009 | 01330 | Odor, Severity | 1/Week | 1 | 0 | 06/08/2009 |
| June 2009 | 50060 | Chlorine, Total Residual | 1/Quarter | 1 | 0 | 06/01/2009 |
| June 2009 | 01330 | Odor, Severity | 1/Week | 1 | 0 | 06/01/2009 |
| June 2009 | 00083 | Color, Severity | 1/Week | 1 | 0 | 06/01/2009 |
| June 2009 | 01350 | Turbidity, Severity | 1/Week | 1 | 0 | 06/01/2009 |
| June 2010 | 50060 | Chlorine, Total Residual | 1/Quarter | 1 | 0 | 06/01/2010 |
| March 2009 | 50060 | Chlorine, Total Residual | 1/Quarter | 1 | 0 | 03/01/2009 |
| March 2009 | 31616 | Fecal Coliform | 1/Quarter | 1 | 0 | 03/01/2009 |
| March 2010 | 50060 | Chlorine, Total Residual | 1/Quarter | 1 | 0 | 03/01/2010 |
| March 2010 | 31616 | Fecal Coliform | 1/Quarter | 1 | 0 | 03/01/2010 |
| March 2011 | 50060 | Chlorine, Total Residual | 1/Quarter | 1 | 0 | 03/01/2011 |
| March 2011 | 31616 | Fecal Coliform | 1/Quarter | 1 | 0 | 03/01/2011 |

Please review the above (apparent) frequency violations to determine if the parameters were ever measured, measured and not reported, or if they were measured and reported incorrectly in the monthly reports to the Agency.


A written explanation of the findings for all the above NPDES permit violations should be submitted to this office within 14 days of the receipt of this correspondence. If the data was collected and either not reported, or was erroneously reported, the eDMR should be amended with correct information.

MAPLEWOOD LOCAL SCHOOL DISTRICT
DECEMBER 8, 2011
PAGE 4

If there are any questions or comments regarding the contents of this letter, please contact this office.

A copy of this inspection report is being forwarded to the Trumbull County Health Department. If you have any comments or questions about this document, you may contact me at (330) 963-1110.

Respectfully,



Charles E. Allen
Environmental Engineer
Division of Surface Water

CEA:bo

pc: Trumbull County Health Dept.

