



**Environmental  
Protection Agency**

John R. Kasich, Governor  
Deborah Pryor, Lt. Governor  
Scott J. White, Director

November 28, 2011

RE: DFC MOBILE HOME PARK WWTP  
NPDES PERMIT NO. 3PV00081  
LENOX TOWNSHIP, ASHTABULA CO.

**NOTICE OF VIOLATION**

**CERTIFIED MAIL**

Ms. Lois Adkins, Owner  
DFC Mobile Home Park and Sales  
1600 Lenox-New Lyme Road  
Jefferson, OH 44047

Dear Ms. Adkins:

During a review of Ohio EPA's electronic discharge monitoring report (eDMR) information for the above referenced facility at 1600 Lenox-New Lyme Road, Lenox Township, Ashtabula County, Ohio EPA notes that the facility is in significant noncompliance (SNC) for ammonia-nitrogen. U.S. EPA defines significant noncompliance for ammonia-nitrogen if a facility exceeds the limits established by the facility's National Pollutant Discharge Elimination System (NPDES) permit by more than 40% for two or more months during the consecutive quarter review. The review period reviewed is January 2010 through August 2011. You were notified of significant noncompliance in letters from this office dated August 5, 2010 November 8, 2010, and October 19, 2011.

***Due to the nature of NPDES permit violations, including failure to follow your compliance schedule, obtain a licensed operator, and continuing violations, this office will be referring this matter to our central office for escalated enforcement.***

If you have any questions or comments regarding this notification, please feel free to contact me at (330) 963-1175.

Respectively,

John M. Schmidt P.E., R.S.  
Environmental Engineer  
Division of Surface Water

JMS/cs

File: Semipublic/Ashtabula/Lenox Twp./DFC MHP (3PV00081)