



**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

December 6, 2011

Dwight McCabe
919 Old Henderson Road
Columbus, OH 43220

**Re: Storm Water Inspection at Permit Number 4GC02548*AG
(Central Park of Gahanna)**

Dear Mr. McCabe,

This letter is written regarding the storm water inspection I conducted at Central Park of Gahanna, in Gahanna, Ohio on November 17, 2011. The Agency understands these construction activities are currently covered under the General Storm Water Permit Associated with Construction Activities. Based on the site inspection and the General Storm Water Permit, the following items were noted:

Sediment Controls

- A large centralized sediment basin was installed to minimize sediment laden run-off from the site.
- Please ensure all barren areas are routed to this basin intended for sediment control. It appears this is the case as all storm is installed.
- All barren and idle areas must be protected from erosion in preparation for the upcoming winter months. Given the time of year, a crimped straw mulch cover or equivalent is expected.

If you have any question regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844 or email at harry.kallipolitis@epa.state.oh.us. A follow-up inspection will be conducted to ensure the conditions of the General Permit are met.

Sincerely,

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

HK/nsm Central Park of Gahanna 11-17-2011