



**Environmental  
Protection Agency**

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

November 25, 2011

Randy Wallace  
Thompson Concrete Construction  
P.O. Box 440  
Carroll, OH 43112

**Re: Election House Road Relocation / Fairfield County**

Dear Mr. Wallace:

This letter is written in follow-up to a construction storm water inspection that I conducted at the Election House Road Relocation project that is located near the Fairfield County Airport. The inspection was conducted on November 17, 2011. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, I noted the following:

**Sediment and Erosion Controls:**

Please be aware the General Permit states that all barren areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. In addition, erosion protection must be implemented for all areas of final grade within seven (7) days. Most of the area appeared to be at or near final grade. Given the time of year, alternate erosion control measures such as erosion control matting, crimped mulching, mulch with netting and/or tackifier, or an approvable alternative must be implement for this site to ensure effective erosion control for the upcoming winter months.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3851.

Sincerely,

Gregory L. Sanders  
Environmental Specialist  
Division of Surface Water  
Central District Office

ec: Greg Sanders, DSW/CDO

GS/nsm Election House Road Relocation, November 17, 2011