



**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

January 3, 2012

Douglas Downs
Shencon Construction
PO Box 2475
Sandusky, OH 44871

**Re: Construction Storm Water Inspection at OHIO BUSINESS COLLEGE / Franklin County,
Permit Number: 4GC03663*AG
NOTICE OF VIOLATION**

Dear Mr. Downs:

This letter is written regarding a storm water inspection I conducted at Ohio Business College off Trueman Blvd. in Hilliard, Ohio on December 15, 2011. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. This letter also serves as a formal Notice of Violation for failure to comply the Construction Storm Water Permit. The following items were noted:

Sediment and Erosion Control:

- A significant portion of the site drains to a centralized pond on the northern end of the facility which is NOT fully installed to date. Corrective measures are expected complete the pond within 10 days from receipt of this letter
- There are significant areas, adjacent to Trueman Blvd, which appear NOT to drain to the pond and are currently uncontrolled .Perimeter controls were established in these areas but have failed due to recent rain events and improper implementation.
- The combination of the two preceding violations resulted in direct uncontrolled discharges to a separate storm sewer system directly adjacent to the project (SEE ATTACHED PHOTO).
- There are significant barren areas noted during this inspection. All barren and idle areas are required to be protected from erosion. Given the time of year, a crimped mulch cover or equivalent is expected.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at harry.kallipolitis@epa.state.oh.us. In addition, please provide a written response to the action items addressed in this letter.

Sincerely,

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW / CDO

