



**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

January 9, 2012

RE: AKRON CANTON REGIONAL AIRPORT
PERMIT NO. 3GC05432*AG
SUMMIT COUNTY
STORM WATER

Richard McQueen
Akron Canton Regional Airport
5400 Lauby Road NW #9
North Canton, Ohio 44720

Dear Mr. McQueen:

On January 6, 2012, this writer conducted a follow-up inspection at the ARFF Snow/Ice Control construction site, permit No. 3GC05432*AG. I was accompanied by Jeffrey Thompson, Project Manager/Construction Manager, G Stephens Inc. The following was noted:

- 1) The sedimentation pond has been constructed at the north end of the site and the outlet installed. The skimmer had not been installed but Mr. Stephens indicated it was on order and should arrive and be installed later that day.
- 2) Mr. Stephens indicated that he would send me a copy of the Storm Water Pollution Prevention Plan (SWPPP) for the site.
- 3) The outlet from the basin flows onto rip rap. Storm water will flow onto rip rap at the outlet before heading in a southerly direction toward the silt trap that has been installed along Mt. Pleasant Road. Please make sure that all controls called out in the SWPPP such as rip rap are installed so that the discharge from the pond does not cause unnecessary erosion.

I will be re-inspecting the site in the near future, once I have received the SWPPP. If you should have any questions concerning the above, feel free to contact this writer at (330) 963-1136 or by e-mail at phil.rhodes@epa.state.oh.us.

Sincerely,

Philip P. Rhodes, P.E.
Environmental Specialist II
Division of Surface Water

PPR/cs

cc: Brian Prunty, Summit Soil and Water Conservation District

File: Construction Storm water/Summit County/City of