

Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

January 9, 2011

Tom Simons
Woda Construction
229 Huber Village Blvd. Suite 100
Westerville, OH 43081

**Re: Construction Storm Water Inspection at Monarch Greene in Franklin County
Permit Number 4GC03173*AG**

Dear Mr. Simons:

This letter is written regarding the storm water inspection I conducted of Monarch Greene in Franklin County on December 21, 2011. The Agency understands these construction activities are currently covered under the General Storm Water Permit Associated with Construction Activities. Based on the site inspection and the General Storm Water Permit, the following items must be addressed:

Sediment and Erosion Controls:

- The site is currently draining to a centralized sediment basin on the eastern portion of the site which appears to be functioning as intended.
- All barren areas which remain idle must be protected from erosion. There are significant barren areas noted during my inspection. Given the time of year a straw mulch cover or equivalent is expected.

If you have any questions regarding this letter or the inspection, please do not hesitate to call me at our Central District Office at (614) 728-3844 or email at harry.kallipolitis@epa.state.oh.us. In addition, please provide a written response (**email preferred**) to the action items addressed above within ten days from receipt of this letter. A follow up inspection will be conducted to ensure the minimum conditions of the General Permit have been met.

Sincerely,



Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

HK/hsm Monarch Greene 12-21-2011

Central District Office
50 West Town Street, Suite 700
P.O. Box 1049
Columbus, OH 43216-1049

614 | 728 3778
614 | 728 3898 (fax)
www.epa.ohio.gov