



Environmental  
Protection Agency

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

January 9, 2012

David Wespiser  
Hotel Development Services  
125 West Spring Street  
Oxford, OH 45058

**Re: Construction Storm Water Inspection at Marriott in New Albany, Ohio  
Permit Number 4GC03490\*AG**

Dear Mr. Wespiser:

This letter is written regarding the storm water inspection I conducted of the construction activities associated with Marriott located at 5211 Forrest Drive in New Albany, Ohio on December 28, 2011. The Agency understands these construction activities are currently covered under the General Storm Water Permit Associated with Construction Activities. Based on the site inspection and the General Storm Water Permit, the following items must be addressed:

**Sediment and Erosion Control:**

- At a minimum, all barren areas which are intended to remain idle to through the winter must be protected with a crimped straw mulch or equivalent. Please be aware that this site will be reevaluated to ensure this minimum requirement is addressed.

**Post Construction Requirements:**

- The General Storm Water Permit requires specific post construction water quality treatment for all sites. Guidance regarding the post construction requirements is found at: <http://www.epa.state.oh.us/dsw/storm/CGPPCQA.aspx>. Please submit to my attention (email preferred at [harry.kallipolitis@epa.state.oh.us](mailto:harry.kallipolitis@epa.state.oh.us)) which practice will be installed at this site to ensure compliance with the General Permit. Please include all design criteria and calculations in your submission.

If you have any question regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844 or email at [harry.kallipolitis@epa.state.oh.us](mailto:harry.kallipolitis@epa.state.oh.us). A follow-up inspection will be conducted to ensure the conditions of the General Permit are met.

Sincerely,

Harry Kallipolitis  
Storm Water Coordinator  
Division of Surface Water  
Central District Office

HK/nsm Marriott-New Albany 12-28-2011