



**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

January 10, 2012

Matt Weber
City of Delaware
1 S Sandusky Street
Delaware, OH 43015

**Re: Construction Storm Water Inspection at Delaware Hotel / Delaware County
Permit Number: 4GCO00015*AG**

Dear Mr. Weber:

This letter is written in follow-up to a construction storm water inspection I conducted at Delaware Hotel in Delaware, Ohio on December 28, 2011. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, our staff noted the following issues associated with construction activities at this site:

Sediment and Erosion Control:

- Stream restoration appears complete. Overall, the stream appears stable with the exception of the extreme downstream portion (SEE ATTACHED PHOTO). Please continue to monitor this area as it appears it may not equalize and continue to erode.

If you have any questions regarding this letter or my inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at harry.kallipolitis@epa.state.oh.us.

Sincerely

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm Delaware Hotel 12-28-2011