



**Environmental  
Protection Agency**

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

January 10, 2012

Phil Wats  
Granville Milling Company  
400 South Main Street  
Granville, OH 43023

**Re: Construction Storm Water Inspection at Granville Milling Company in  
Johnstown, Ohio on December 28, 2011  
Permit Number 4GC03654\*AG**

Dear Mr. Wats:

This letter is written regarding the storm water inspection I conducted of the construction activities of Granville Milling Company in Johnstown Ohio on December 28, 2011. The Agency understands these construction activities are currently covered under the General Storm Water Permit Associated with Construction Activities. Based on the site inspection and the General Storm Water Permit, the following items were noted:

**Sediment and Erosion Control:**

1. I noted site construction has recently started and perimeter silt fence is installed. Please maintain all perimeter silt fence as required by your General Permit.
2. The sediment basins appear full and require maintenance. In addition, I am formally requesting the design criteria for the ponds as they appear undersized.
3. Please utilize diversions, as necessary to ensure all barren areas are routed to the basin intended for sediment control. Specifically for the areas south and west of the construction entrance. A culvert under the road should be utilized to direct all drainage from the site to the ponds intended for sediment control.
4. All barren areas which remain idle must be protected from erosion. Given the time of year a crimped straw mulch cover, or equivalent is expected.

**Post Construction Requirements:**

- The General Storm Water Permit requires specific post construction water quality treatment for all sites. Guidance regarding the post construction requirements is found at: <http://www.epa.state.oh.us/dsw/storm/CGPPCQA.aspx>. Please submit to my attention (email preferred at [harry.kallipolitis@epa.state.oh.us](mailto:harry.kallipolitis@epa.state.oh.us)) which practice will be installed at this site to ensure compliance with the General Permit. Please include all design criteria and calculations in your submission.

If you have any questions regarding this letter or the inspection, please do not hesitate to call me at our Central District Office at (614) 728-3844 or email at [harry.kallipolitis@epa.state.oh.us](mailto:harry.kallipolitis@epa.state.oh.us). In addition, please provide a written response (**email preferred**) to the action items addressed above within ten days from receipt of this letter. A follow-up inspection will be conducted to ensure the minimum conditions of the General Permit have been met.

Sincerely,



Harry Kallipolitis  
Storm Water Coordinator  
Division of Surface Water  
Central District Office