Ohio | Environmental Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

January 12, 2012

Mr. Chris Inverso
Provider Services
16320 Kaylor Road
Danville, Ohio 43014

Re: Butler County, Golden Years Healthcare, NPDES Permit Violations

Dear Mr. Inverso:

We have reviewed your Monthly Operating Reports covering the months of July through November 2011 for the referenced facility. Our review indicates violations of the conditions of your NPDES Permit (NPDES Permit # OH0118397; OEPA Permit # 1PT00079*CD and 1PT00079*DD). The specific instances of noncompliance were as follows:

Effluent Limit Violations for June through November 2011					
Reporting Period	Parameter	Limit Type	Units	Permit Limit	Reported Value
July 2011	TSS	Monthly	mg/l	12	54
July 2011	TSS	Weekly	mg/l	18	54
August 2011	TSS	Monthly	mg/l	12	15

Please be advised that failure to comply with the effluent limitations of your NPDES Permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

We have reviewed your reports addressing the reasons for the above violations and the actions being taken to prevent further occurrences. No additional information is requested at this time. Future violations must continue to be reported as required by the NPDES Permit as detailed in Part III.12 titled "Noncompliance Notification."

Southwest District Office
401 East Fifth Street
Dayton, OH 45402-2911

937 | 285 6357
937 | 285 6249 (fax)
www.epa.ohio.gov

If you have any questions regarding the above, please contact me at (937) 285-6096.

Sincerely,

Ned Sarle
Division of Surface Water
Permit Section

ec: Michael Wisecarver, Wisecarver Environmental
Tim Poynter, Poynter Waste Water Services, LLC