Ohio | Environmental Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

January 3, 2012

Mayor & Council
City of Hillsboro
130 North High Street
Hillsboro, OH 45133

Re: Hillsboro WWTP- 1PC00100*ID
Notice of Violation

Ladies & Gentlemen:

A compliance review was conducted on your Discharge Monitoring Report (DMR) submitted on December 29, 2011. As detailed at the end of this letter, screening of your submitted DMR has identified compliance issues.

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES Permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

We have reviewed your report addressing the reasons for the above violations and the actions being taken to prevent further occurrences. No additional information is requested at this time. Future violations must continue to be reported as required by the NPDES Permit as detailed in Part III.12 titled "Non-compliance Notification".

If you should have any questions, feel free to contact me by phone at (937) 285-6029 or by electronic mail at Joshua.Jackson@epa.state.oh.us.

Respectfully,

Joshua Jackson
Environmental Specialist II
Division of Surface Water

Ec: Brandon Leeth, City of Hillsboro (bleeth@hillsboroohio.net)

Southwest District Office
401 East Fifth Street
Dayton, OH 45402-2911

937 | 285 6357
937 | 285 6249 (fax)
www.epa.ohio.gov

Ohio | Environmental Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

Notice of Violation Report

Facility: Hillsboro WWTP

Permit No.: 1PC00100*ID

Report Period: November 2011 **Date Received:** 12/29/2011

Station	Type	Date	Reporting Code	Parameter	Limit Type	Permit Limit	Reported Value
001	Limit	11/1/2011	00530	Total Suspended Solids	Monthly Load	77.3	97.8600
001	Limit	11/22/2011	00530	Total Suspended Solids	Weekly Load	118.2	303.685
001	Freq	11/22/2011	00530	Total Suspended Solids	3/Week	3	2
601	Freq	11/22/2011	00530	Total Suspended Solids	3/Week	3	2
001	Freq	11/22/2011	00610	Nitrogen, Ammonia (NH3)	3/Week	3	2
001	Limit	11/1/2011	00665	Phosphorus, Total (P)	Monthly Load	4.5	5.8278
001	Limit	11/8/2011	00665	Phosphorus, Total (P)	Weekly Conc.	1.5	1.61
001	Limit	11/8/2011	00665	Phosphorus, Total (P)	Weekly Load	6.8	10.7617
001	Limit	11/22/2011	00665	Phosphorus, Total (P)	Weekly Load	6.8	10.6707
001	Limit	11/1/2011	50092	Mercury, Total (Low Level)	Monthly Conc.	12	15.275
001	Limit	11/1/2011	50092	Mercury, Total (Low Level)	Monthly Load	0.0000	.00008
001	Limit	11/22/2011	80082	CBOD 5 day	Weekly Load	104.6	138.069
001	Freq	11/22/2011	80082	CBOD 5 day	3/Week	3	2
601	Freq	11/22/2011	80082	CBOD 5 day	3/Week	3	2