



Environmental  
Protection Agency

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

January 17, 2012

Mayor & Council  
Village of Yellow Springs  
100 Dayton Street  
Yellow Springs, OH 45387

**Re: Yellow Springs WWTP- 1PC00013\*ID  
Notice of Violation**

Ladies & Gentlemen:

A compliance review was conducted on your Discharge Monitoring Report (DMR) submitted on January 12, 2012. As detailed at the end of this letter, screening of your submitted DMR has identified compliance issues.

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES Permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

Please inform this office, in writing, within ten days of receipt of this notification as to the reasons for the above referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions. Future violations must be reported as required by the NPDES Permit as detailed in Part III.12 titled "Non-compliance Notification".

If you should have any questions, feel free to contact me by phone at (937) 285-6029 or by electronic mail at [Joshua.Jackson@epa.state.oh.us](mailto:Joshua.Jackson@epa.state.oh.us).

Respectfully,

Joshua Jackson  
Environmental Specialist II  
Division of Surface Water

Ec: [JBates@yso.com](mailto:JBates@yso.com)



**Environmental  
Protection Agency**

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

**Notice of Violation Report**

---

**Facility:** Yellow Springs WWTP

**Permit No.:** 1PC00013\*ID

**Report Period:** December 2011

**Date Received:** 1/12/2012

Station	Type	Date	Reporting Code	Parameter	Limit Type	Permit Limit	Reported Value
001	Limit	12/1/2011	00530	Total Suspended Solids	Weekly Load	40.9	48.3666