



Environmental  
Protection Agency

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

January 18, 2012

Carolyn Pottschmidt  
Hamilton County Park District  
10245 Winton Road  
Cincinnati, Ohio 45231

RE: Miami Whitewater Forest Park WWTP  
NPDES Permit 1PG00056\*ID, OH0047261  
Notice of Violation

Dear Ms. Pottschmidt:

I have conducted a compliance review of this permit for the past 6 months. My review indicates a few violations of the conditions of the NPDES permit for the facility. The specific instances of non-compliance are as follows:

**EFFLUENT LIMIT VIOLATIONS AT OUTFALL 1PG00056001**

<u>Parameter</u>	<u>Date</u>	<u>Permit Limit</u>	<u>Value Reported</u>
Dissolved Oxygen	7/16/2011	6.0 mg/l	0.001 mg/l
Chlorine, TR	9/23/2011	0.019 mg/l	0.13 mg/l

As required under the permit, non-compliance notifications were sent to this agency regarding the above violations. No further response is necessary.

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111. If you have any questions about this letter, please contact me at (937) 285-6101.

Sincerely,

Mary Osika  
Environmental Specialist  
Division of Surface Water