Ohio | Environmental Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

January 19, 2012

Bill Freppon
Eastview Water Treatment, Inc.
4628 Boomer Road
Cincinnati, Ohio 45247

RE: Eastview WWTP
NPDES Permit 1PZ00060*DD, OH0118168
Notice of Violation

Dear Mr. Freppon:

I have conducted a compliance review of this wastewater treatment plant for the past 6 months. My review indicates several violations of the conditions of the NPDES permit for the facility. The specific instances of non-compliance are as follows:

EFFLUENT LIMIT VIOLATION AT OUTFALL 1PZ00060001

Parameter	Date	Permit Limit	Value Reported
Chlorine, TR	6/22/2011	0.019 mg/l	0.1 mg/l

MONITORING VIOLATION AT OUTFALL 1PZ00060001

Parameter	Date	Permit Freq.	Reported
T. Susp. Solids	8/1/2011	1	0
Nitrogen, Ammonia	8/1/2011	1	0
E. Coli	8/1/2011	1	0
CBOD 5day	8/1/2011	1	0

Non-compliance notifications were not sent to this agency regarding the above violations, as required by the conditions in the permit. A written non-compliance notification should be sent whenever there is a limit violation, plant upset, bypass or monitoring violation.

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for

Southwest District Office
401 East Fifth Street
Dayton, OH 45402-2911

937 | 285 6357
937 | 285 6249 (fax)
www.epa.ohio.gov

enforcement action pursuant to the Ohio Revised Code Chapter 6111. A response to this Notice of Violation is required by January 31, 2012 discussing causes of the listed violations and actions that will be taken to prevent their reoccurrence. If you have any questions about this letter, please contact me at (937) 285-6101.

Sincerely,

Mary Osika
Environmental Specialist
Division of Surface Water

ec: Dennis Feichtner, Operator of Record