



Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

January 20, 2012

Gary Bruewer
Bruewer Woodwork Manufacturing Company
10000 Cilley Road
Cleves, Ohio 45002

RE: Bruewer Woodwork WWTP
NPDES Permit 1PR00106*BD, OH0118931
Notice of Violation

Dear Mr. Bruewer:

I have conducted a compliance review of this wastewater treatment plant for the past 6 months. My review indicates several violations of the conditions of the NPDES permit for the facility. The specific instances of non-compliance are as follows:

EFFLUENT LIMIT VIOLATIONS AT OUTFALL 1PR00106001

<u>Parameter</u>	<u>Date</u>	<u>Permit Limit</u>	<u>Value Reported</u>
Nitrogen, Ammonia	6/1/2011	1.0 mg/l	1.1 mg/l
Chlorine, TR	6/22/2011	0.019 mg/l	0.1 mg/l

MONITORING VIOLATIONS AT OUTFALL 1PR00106001

<u>Parameter</u>	<u>Date</u>	<u>Permit Freq.</u>	<u>Reported</u>
T. Susp. Solids	8/1/2011	1	0
Nitrogen, Ammonia	8/1/2011	1	0
Fecal Coliform	8/1/2011	1	0
CBOD 5day	8/1/2011	1	0
Chlorine, TR	8/1/2011	1	0
pH	8/1/2011	1	0
Dissolved Oxygen	8/1/2011	1	0

Gary Bruewer
January 20, 2012
Page 2

Non-compliance notifications were not sent to this agency regarding the above violations, as required by the conditions in the permit. A written non-compliance notification should be sent to me whenever there is a limit violation, plant upset, bypass or monitoring violation.

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

A response to this Notice of Violation is required by February 3, 2012 discussing the causes of the listed violations and actions that will be taken to prevent their reoccurrence. If you have any questions about this letter, please contact me at (937) 285-6101.

Sincerely,

Mary Osika
Environmental Specialist
Division of Surface Water

ec: Dennis Feichtner, Operator of Record