



Environmental  
Protection Agency

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

January 20, 2012

Mark Kreimer  
Kreimer's Bier Haus  
P.O. Box 111  
Miamitown, Ohio 45041

RE: Kreimer's WWTP  
NPDES Permit 1PZ00064\*BD, OH0118354  
Notice of Violation

Dear Mr. Kreimer:

I have conducted a compliance review of this wastewater treatment plant for the past 6 months. My review indicates several violations of the conditions of the NPDES permit for the facility. The specific instances of non-compliance are as follows:

**EFFLUENT LIMIT VIOLATIONS AT OUTFALL 1PZ00064001**

<u>Parameter</u>	<u>Date</u>	<u>Permit Limit</u>	<u>Value Reported</u>
Chlorine, TR	6/1/2011	0.019 mg/l	0.1 mg/l
Nitrogen, Ammonia	6/1/2011	1.0 mg/l	1.4 mg/l
Nitrogen, Ammonia	8/1/2011	1.0 mg/l	1.1 mg/l

**MONITORING VIOLATION AT OUTFALL 1PZ00064001**

<u>Parameter</u>	<u>Date</u>	<u>Permit Freq.</u>	<u>Reported</u>
Oil & Grease	8/1/2011	1	0

Non-compliance notifications were not sent to this agency regarding the above violations, as required by the conditions in the permit. A written non-compliance notification should be sent to me whenever there is a limit violation, plant upset, bypass or monitoring violation.

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

Mark Kreimer  
January 20, 2012  
Page 2

A response to this Notice of Violation is required by February 3, 2012 discussing the causes of the listed violations and actions that will be taken to prevent their reoccurrence. If you have any questions about this letter, please contact me at (937) 285-6101.

Sincerely,

A handwritten signature in black ink, appearing to read "Mary Osika", with a stylized, cursive script.

Mary Osika  
Environmental Specialist  
Division of Surface Water

cc: Dennis Feichtner, Operator of Record