



**Environmental
Protection Agency**

John R. Kasich, Governor

Mary Taylor, Lt. Governor

Scott J. Nally, Director

January 20, 2012

RE: SUMMIT COUNTY
FRANKLIN TOWNSHIP
REX HILL MOBILE ESTATES
COMPLIANCE EVALUATION INSPECTION
NPDES NO. OH0098442
OHIO EPA NO. 3PV00049*DD

Mr. Jess Belton Jr., Owner
14961 Oak Grove Drive
Doylestown, OH 44230

Dear Mr. Belton:

On January 17, 2012, a compliance evaluation inspection was conducted at the wastewater treatment plant (WWTP) serving Rex Hill Mobile Estates. The plant consists of a 3735-gallon trash trap, a 765-gallon trash trap, a 30,000 gpd extended aeration treatment plant, a 1500-gallon dosing station, a 2500 square foot surface sand filter, chlorination/dechlorination, a 3000-gallon aerated sludge storage tank, and a 468 square foot sludge drying bed. The plant discharges to an unnamed tributary to the Tuscarawas River.

During the inspection the following observations were made:

1. The WWTP was running and had no offensive odor. The mixed liquor in the aeration tank did appear slightly dark with some dark foam.
2. One clarifier looked good with clear water in the effluent trough. One clarifier had lots of solids build-up with solids flowing over the weir. As soon as possible, this clarifier should be maintained. All return lines appeared to be working properly.
3. The aerated sludge storage tank did not appear to be receiving air. Repairs should be made as soon as possible.
4. The sludge drying beds don't appear to be utilized.
5. The effluent in the disinfection tank appeared clear of any visible solids.

Upon reviewing your Discharge Monitoring Reports (DMR) from January 2010 to January 2012, the following effluent violations were noted:

Reporting Period	Parameter	Limit Type	Limit	Reported Value	Violation Date
May 2011	Fecal Coliform	30D Conc	1000	3200.	5/1/2011
May 2011	Fecal Coliform	7D Conc	2000	3200.	5/15/2011
August 2011	Fecal Coliform	30D Conc	1000	3000.	8/1/2011
August 2011	Fecal Coliform	7D Conc	2000	3000.	8/15/2011


Please be advised such instances of noncompliance are subject to enforcement pursuant to Ohio Revised Code (ORC) 6111.

REX HILL MOBILE ESTATES
JANUARY 20, 2012
PAGE 2 OF 2

In conclusion, operation and maintenance of the plant appears to be satisfactory and this office has no concerns. The plant appears to be producing a good effluent.

If you have any questions, please contact this office at (330) 963-1151.

Sincerely,

A handwritten signature in black ink, appearing to read "Jennifer S. Bennage". The signature is written in a cursive, flowing style.

Jennifer S. Bennage
Environmental Engineer
Division of Surface Water

JSB/cs

cc: Mr. Richard Jackson, Certified Operator
Mr. Brent Paulus, Summit County Health Dept.
Jackson