



Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

January 18, 2012

Tucker Bohm
Daimler Group
1533 Lake Shore Drive
Columbus, OH 43204

**Re: Construction Storm Water Inspection at Water's Edge Phase 2
Franklin County
Permit Number: 4GC03501 *AG**

Dear Mr. Bohm:

This letter is written regarding a storm water inspection I conducted at Water's Edge located at 7795 Walton Parkway New Albany, Ohio on January 4, 2012. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit associated with Construction Activities. During the inspection, our staff noted the following issues associated with construction activities at this site:

Sediment and Erosion Control:

- It appears all disturbed areas are properly routed to the centralized basin intended for sediment control. Please ensure the pond is maintained throughout all construction phases.
- Please be aware measures are expected to ensure all barren areas are properly protected in preparation for the upcoming winter months. Given the time of year a crimped mulch cover is expected for all barren areas, including the large stockpiles located on the eastern portion of the site.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at harry.kallipolitis@epa.state.oh.us.

Sincerely,

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW / CDO

HK/nsm Water's Edge Phase 2 8-23-2011

Central District Office
50 West Town Street, Suite 700
P.O. Box 1049
Columbus, OH 43216-1049

614 | 728 3778
614 | 728 3898 (fax)
www.epa.ohio.gov