



Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

January 12, 2012

Mr. Brian Bremer
Crouse MHP
4141 Hamilton Eaton Road
Hamilton, Ohio 45011

Re: Butler County, Crouse MHP, NPDES Permit Violations

Dear Mr. Bremer:

We have reviewed your Discharge Monitoring Reports (DMRs) covering the month of November 2011 for the referenced facility. Our review indicates violations of the conditions of your NPDES Permit (NPDES Permit # OH0118923; OEPA Permit # 1PV00095*DD). The specific instances of noncompliance were as follows:

Effluent Limit Violations for November 2011					
Reporting Period	Parameter	Limit Type	Units	Permit Limit	Reported Value
November 2011	Ammonia	Monthly	mg/l	5.0	8.5
November 2011	Ammonia	Weekly	mg/l	7.5	17

Please be advised that failure to comply with the effluent limitations or to satisfy the reporting requirements of your NPDES Permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

We have reviewed your report addressing the reasons for the above violations and the actions being taken to prevent further occurrences. No additional information is requested at this time. Future violations must continue to be reported as required by the NPDES Permit as detailed in Part III.12 titled "Noncompliance Notification."

If you have any questions regarding the above, please contact me at (937) 285-6096.

Sincerely,

Ned Sarle
Division of Surface Water
Permit Section

cc: Eric Gibson, Winelco, Inc.

Southwest District Office
401 East Fifth Street
Dayton, OH 45402-2911

937 | 285 6357
937 | 285 6249 (fax)
www.epa.ohio.gov