



Environmental  
Protection Agency

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

January 19, 2012

Paul Ritter  
Holiday Homes  
1252 Goshen Pike  
Milford, Ohio 45150

RE: Riverview Crossing MHP WWTP  
NPDES Permit 1PV00096\*DD, OH0118974  
Notice of Violation

Dear Mr. Ritter :

I have conducted a compliance review of this wastewater treatment plant for the past 6 months. My review indicates several violations of the conditions of the NPDES permit for the facility. The specific instances of non-compliance are as follows:

**EFFLUENT LIMIT VIOLATION AT OUTFALL 1PV00096001**

<u>Parameter</u>	<u>Date</u>	<u>Permit Limit</u>	<u>Value Reported</u>
pH	8/10/2011	6.5 S.U.	6.0 S.U.

**MONITORING VIOLATIONS AT OUTFALL 1PV00096001**

<u>Parameter</u>	<u>Date</u>	<u>Permit Freq.</u>	<u>Reported</u>
T. Susp. Solids	6/8/2011	2	1
F. Coliform	6/8/2011	1	0
CBOD 5day	6/8/2011	2	1
T. Susp. Solids	11/22/2011	2	1
CBOD 5day	11/22/2011	2	1

Non-compliance notifications were not sent to this agency regarding the above violations, as required by the conditions in the permit. A written non-compliance notification should be sent whenever there is a limit violation, plant upset, bypass or monitoring violation.

Paul Ritter  
January 19, 2012  
Page 2

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111. A response to this Notice of Violation is required by January 31, 2012 discussing causes of the listed violations and actions that will be taken to prevent their reoccurrence. If you have any questions about this letter, please contact me at (937) 285-6101.

Sincerely,

A handwritten signature in black ink, appearing to read "Mary Osika", with a long horizontal flourish extending to the right.

Mary Osika  
Environmental Specialist  
Division of Surface Water

cc: Dennis Feichtner, Operator of Record