



Environmental  
Protection Agency

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

January 20, 2012

Ray Ruess  
Woodlands Reception Hall  
9680 Cilley Road  
Clevs, Ohio 45002

RE: Woodlands WWTP  
NPDES Permit 1PX00030\*BD, OH0132161  
Notice of Violation

Dear Mr. Ruess:

I have conducted a compliance review of this wastewater treatment plant for the past 6 months. My review indicates several violations of the conditions of the NPDES permit for the facility. The specific instances of non-compliance are as follows:

**EFFLUENT LIMIT VIOLATION AT OUTFALL 1PX00030001**

<u>Parameter</u>	<u>Date</u>	<u>Permit Limit</u>	<u>Value Reported</u>
Fecal Coliform	6/1/2011	1000 counts	1150 counts

**REPORTING CODE VIOLATION AT OUTFALL 1PX00030001**

<u>Parameter</u>	<u>Date</u>	<u>Reporting Code Used</u>	<u>Explanation</u>
Fecal Coliform	9/16/2011	AB (data lost)	none

A non-compliance notification was not sent to this agency regarding the above violations, as required by the conditions in the permit. A written non-compliance notification should be sent to me whenever there is a limit violation, plant upset, bypass or monitoring violation.

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

Ray Ruess  
January 20, 2012  
Page 2

A response to this Notice of Violation is required by February 3, 2012 discussing the causes of the listed violations and actions that will be taken to prevent their reoccurrence. If you have any questions about this letter, please contact me at (937) 285-6101.

Sincerely,

Mary Osika  
Environmental Specialist  
Division of Surface Water

ec: Winelco, Inc.