



**Environmental  
Protection Agency**

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

Re: Richland County  
Jozz Lounge & Mansfield Inn  
NPDES Permit  
**Notice of Violation**

January 23, 2012

Mr. Joe Sennett  
880 Laver Road  
Mansfield, Ohio 44905

Dear Mr. Sennett,

On January 11, 2012, an inspection was made of the wastewater treatment facilities serving Jozz Lounge and the Mansfield Inn located at 880 Laver Road and U.S. 30, Mansfield, Richland County. At the time of the inspection, all of the major treatment units were in operation and appeared to be functioning normally.

The backup aeration blower was present; however, it was not wired into the control panel. The blower needs to be made ready for use and wired into the controls. This was mentioned during our previous two inspections. A large amount of trash and sludge were present behind the influent baffle in the clarifier tank. This material should be pumped out of the treatment plant.

A review of the discharge monitoring reports submitted to our office for the months of February through December 2011 revealed numerous **violations** of the limits contained in your NPDES permit. A printout of these **violations** has been enclosed for your records. Your current NPDES permit expires on January 31, 2012. As of the date of this letter, we have yet to receive a renewal NPDES application. Your permit requires that a complete renewal application, with appropriate fees, be submitted to our office no later than 180 days prior to the permit expiring. Failure to submit a renewal application is a **violation** of your NPDES permit. The application, with appropriate, fees should be submitted by February 1, 2012.

Your NPDES discharge permit contains a compliance schedule to install plant upgrades or connect to sewer. You are currently in **violation** of the compliance schedule contained in the NPDES permit. You have not met any of the three compliance milestone dates outlined in the NPDES permit, which were August 1, 2008 – submit detailed plans, August 1, 2009 – commence construction, February 1, 2010 - meet final effluent limits. Our office has begun drafting a referral for escalated enforcement action recommending Director's Final Findings and Orders requiring implementation of the NPDES permit conditions. You should be receiving a copy of these Orders within the next 60-90 days.

Please call me at 419-373-3070 if you have any questions.

Sincerely,

Walter Ariss  
Environmental Specialist II  
Division of Surface Water

/jlm

Enclosure

pc: Lonnie McGhee, MTWSI  
Steven Risser, PE, Richland County Building Department  
ec: Inspection Tracking

Get New Data		Joez Lounge NPDES permit limit violations February through December 2011						
Permit No	Reporting Period	Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
2PR00238*AD	March 2011	001	00610	Nitrogen, Ammonia (NH3	30D Conc	3.0	6.39	3/1/2011
2PR00238*AD	March 2011	001	80082	CBOD 5 day	30D Conc	10	15.6	3/1/2011
2PR00238*AD	March 2011	001	00610	Nitrogen, Ammonia (NH3	1D Conc	4.5	6.39	3/23/2011
2PR00238*AD	March 2011	001	80082	CBOD 5 day	1D Conc	15	15.6	3/23/2011
2PR00238*AD	April 2011	001	00530	Total Suspended Solids	30D Conc	12	15.2	4/1/2011
2PR00238*AD	May 2011	001	31616	Fecal Coliform	30D Conc	1000	4200.	5/1/2011
2PR00238*AD	May 2011	001	31616	Fecal Coliform	1D Conc	2000	4200.	5/11/2011
2PR00238*AD	July 2011	001	00610	Nitrogen, Ammonia (NH3	30D Conc	1.0	1.38	7/1/2011
2PR00238*AD	July 2011	001	31616	Fecal Coliform	30D Conc	1000	20000.	7/1/2011
2PR00238*AD	July 2011	001	31616	Fecal Coliform	1D Conc	2000	20000.	7/13/2011
2PR00238*AD	August 2011	001	00530	Total Suspended Solids	30D Conc	12	21.2	8/1/2011
2PR00238*AD	August 2011	001	00530	Total Suspended Solids	1D Conc	18	21.2	8/24/2011
2PR00238*AD	September 2011	001	31616	Fecal Coliform	30D Conc	1000	5700.	9/1/2011
2PR00238*AD	September 2011	001	31616	Fecal Coliform	1D Conc	2000	5700.	9/14/2011
2PR00238*AD	October 2011	001	31616	Fecal Coliform	30D Conc	1000	4200.	10/1/2011
2PR00238*AD	October 2011	001	31616	Fecal Coliform	1D Conc	2000	4200.	10/5/2011
2PR00238*AD	November 2011	001	80082	CBOD 5 day	30D Conc	10	13.	11/1/2011
2PR00238*AD	December 2011	001	00530	Total Suspended Solids	30D Conc	12	36.	12/1/2011
2PR00238*AD	December 2011	001	00530	Total Suspended Solids	1D Conc	18	36.	12/7/2011