



Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

January 23, 2012

Mr. Tom Sears
Village of Farmersville
117 East Walnut
Farmersville, OH 45325

Re: Montgomery County, Village of Farmersville, Compliance Evaluation Inspection
and Notice of Violation

Dear Mr. Sears:

On January 11, 2012, I conducted a Compliance Evaluation Inspection at the Village of Farmersville Wastewater Treatment Plant (NPDES Permit - OH0020770; OEPA Permit - 1PB00010*HD) located at 4850 Germantown-Farmersville Pike. Representing the facility was Mr. Gary Wagner and Mr. Aaron Buzbee.

I have included with this letter a copy of the inspection report and General Lab Criteria. Two of the areas evaluated during the inspection were found to be "Marginal". The areas found to be "Marginal" were the Laboratory and Self Monitoring sections of the inspection and corrective actions will be required. A summary of the findings are as follows:

Observation(s):

- The Standard Operating Procedures need to be modified to reflect the laboratory practices and equipment in use at the Village of Farmersville. The SOP for pH will need to be customized for the analysis performed at the Village of Farmersville. The SOP for the analysis of CBOD will need to be revised to include DO analysis.
- The facility calibrates all of the thermometers used in the laboratory using an NIST traceable thermometer. The calibration for the NIST traceable thermometer had recently expired. The facility will need to have the calibration for the NIST traceable thermometer recertified.
- Permit 1PB00010*MD requires the facility to collect 24 hour composite samples. The facility is in the process of purchasing an automatic sampler. The automatic sampler will need to be installed to collect samples proportional to the flow through the WWTP.

Please inform this office, in writing, within ten days of receipt of this notification as to the actions proposed to address the observations noted above. Your response should include the dates, either actual or proposed, for completion of said actions.

Violation(s):


- The facility experienced a violation of the Final Effluent limit for Fecal Coliform. Details of this violation can be found in Attachment 1 of the inspection report.

Please inform this office, in writing, within ten days of receipt of this notification as to the reason for the above referenced violation, as well as a description of the actions taken or proposed to prevent further violations. Your response should include the dates, either actual or proposed, for completion of said actions. Please be advised that failure to comply with the effluent limitations, monitoring, or reporting requirements of your NPDES Permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

It was noted during the inspection that Mr. Wagner is on file as being the Operator of Record and is not an employee of the Village of Farmersville. During the inspection Mr. Buzbee indicated a desire to become a Certified Class I Wastewater Treatment Operator. I encourage Mr. Buzbee to pursue this certification.

If you have any questions regarding this report please feel free to contact me at (937) 285-6107 or via email at: robert.ostendorf@epa.ohio.gov.

Sincerely,



Bob Ostendorf Jr.
Division of Surface Water
Permits Section

Enclosures





State of Ohio Environmental Protection Agency
Southwest District Office

NPDES Compliance Inspection Report

Section A: National Data System Coding					
Permit #	NPDES#	Month/Day/Year	Inspection Type	Inspector	Facility Type
1PB00010*HD	OH0020770	1/11/12	C	S	1

Section B: Facility Data		
Name and Location of Facility Inspected	Entry Time	Permit Effective Date
Village of Farmersville 4850 Germantown-Farmersville Pike Farmersville, OH 45325	0935	April 1, 2007
	Exit Time	Permit Expiration Date
	1130	March 31, 2012
Name(s) and Title(s) of On-Site Representatives	Phone Number(s)	
Mr. Aaron Buzbee, Service Technician Mr. Gary Wagner, ORC	(937) 696-2020	
Name, Address and Title of Responsible Official	Phone Number	
Mr. Tom Sears, Village Administrator Village of Farmersville 117 East Walnut Street Farmersville, OH 45325	(937) 696-2020	

Section C: Areas Evaluated During Inspection					
(S = Satisfactory, M = Marginal, U = Unsatisfactory, N = Not Evaluated)					
S	Permit	S	Flow Measurement	N	Pretreatment
S	Records/Reports	M	Laboratory	S	Compliance Schedule
S	Operations & Maintenance	S	Effluent/Receiving Waters	M	Self-Monitoring Program
N	Facility Site Review	S	Sludge Storage/Disposal	S	Other
N	Collection System				

Section D: Summary of Findings (Attach additional sheets if necessary)	
Please see the cover letter for a summary of the findings. The details of the findings are documented within this inspection report.	
Inspector	Reviewer
 Bob Ostendorf Jr. Division of Surface Water Southwest District Office	 Martyn Burt Compliance & Enforcement Supervisor Division of Surface Water Southwest District Office
1-23-12 Date	1/24/12 Date

Sections E thru K: Complete on all inspections as appropriate
Y – Yes, N – No, N/A – Not Applicable, N/E – Not Evaluated

Section E: Permit Verification

Inspection observations verify the permit

- | | |
|--|---|
| (a) Correct name and mailing address of permittee | Y |
| (b) Flows and loadings conform with NPDES permit..... | Y |
| (c) Treatment processes are as described in permit application... | Y |
| (d) All discharges are permitted..... | Y |
| (e) Number and location of discharge points are as described
in permit..... | Y |
| (f) Storm water discharges properly permitted..... | Y |

Comments/Status:

Section F: Compliance

- | | |
|---|-----|
| (a) Any significant violations since the last inspection..... | N |
| (b) Appropriate Non-compliance notification of violations..... | N/A |
| (c) Permittee is taking actions to resolve violations..... | N/A |
| (d) Permittee has a compliance schedule..... | Y |
| (e) Compliance schedule contained in...Administrative Orders | |
| (f) Permittee is in compliance with schedule..... | Y |
| (g) Has biomonitoring shown toxicity in discharge since last inspection | N |

Comments/Status:

Section G: Operation & Maintenance

Treatment Works:

Treatment facility properly operated and maintained

- (a) Standby power available.....generator or dual feed Y
 - i. What does the back-up power source operate.....

The generator is located onsite and is capable of operating the entire treatment plant.
 - ii. How often is the generator tested under load.....

- (b) Which components have an alarm system available for power or equipment failures.....

The WWTP and the nearby lift station are served by the same power source and the lift station is equipped with a visual alarm and has call out capabilities. The balance of the lift stations also have visual alarms.

- (c) All treatment units in service other than backup units..... Y
- (d) What method is used for scheduling routine & preventative maintenance (calendar, software, etc.).....

The facility has developed a checklist for the routine maintenance performed at the facility.
- (e) Any major equipment breakdown since last inspection..... N
- (f) Operation and maintenance manual provided and maintained..... N
- (g) Any plant bypasses since last inspection..... N
- (h) Any plant upsets since last inspection..... N

Comments/Status:

Section G: Operation & Maintenance con't

Record Keeping/Operator of Record:

- (a) Wastewater Treatment Works classification (OAC 3745-7)..... I
- (b) Operator of Record holds unexpired license of class required by Permit..... Y
- (c) Copy of certificate of Operator of Record displayed on-site..... Y
- (d) Has the Operator of Record submitted an ORC Notification form.. Y
- (e) Minimum operator staffing requirements fulfilled (OAC 3745-7).... N/A
- (f) If a Staffing Reduction plan has been approved, are the stipulations of the plan being met..... N/A
- (g) Operator of Record log book provided..... Y
- (h) Format of log book (e.g. computer log, hard bound book)

Hard bound book

- (i) Log book kept onsite (in an area protected from weather)..... Y
- (j) Log book contains the following:
 - I. Identification of treatment works..... Y
 - II. Date/times of arrival/departure for Operator of Record and any other operator required by OAC 3745-7..... Y
 - iii. Daily record of operator and maintenance activities (including preventative maintenance, repairs and request for repairs, process control test results, etc.)..... Y
 - iv. Laboratory results (unless documented on bench sheets)... Y
 - v. Identification of person making entries..... Y
- (k) Has the Operator of Record submitted written notifications to the permittee, Ohio EPA and, if applicable, any local environmental agencies when a collection system overflow, treatment plant bypass or effluent limit violation has occurred..... N/A

Comments/Status:

The maintenance activities are recorded in a separate logbook maintained by onsite staff.

Section G: Operation & Maintenance con't

Collection System:

- (a) Are there pump stations in the collection system..... Y (5)
 - i. How many publicly-owned pump stations equipped with permanent standby power or equivalent.....1
 - ii. How many pump stations have telemetered alarms.....1
 - iii. How many pump stations have operable alarms.....5

- (b) Any chronic collection system overflows since last inspection..... N
- (c) Regulatory agency notified of all overflows..... N/A
- (d) Are there CSOs in the collection system..... N/A
if so, what is the LTCP status.....
- (e) How are CSOs monitored (chalk, block, level sensor, etc.).....
- (f) Portable pumps available for collection system maintenance..... Y
- (g) RDII Program established and active..... N/E
- (h) Any WIB complaint received since last inspection..... N
- (i) Is there a WIB response plan..... N
- (j) Is any portion of the collection system at or near dry weather capacity..... N

Comments/Status:

Section H: Sludge Management

- (a) Method of Sludge Disposal... Land Application
 Haul to Another NPDES Permittee
 Haul to a Mixed Solid Waste Landfill

*if one of the selected methods is land application, complete applicable charts.
Class A - Exception Quality Sewage Sludge (monitoring station 584)

Pathogen Reduction Alternative	84370 Vector Attraction Reduction Options							
	Option 1 -38% Volatile Solids Reduction	Option 2 -Anaerobic Bench Scale Analysis	Option 3 – Aerobic Bench Scale Analysis	Option 4 – Specific Oxygen Uptake Rate	Option 5 – Aerobic Time and Temperature	Option 6 – Alkali Addition	Option 7 – >75% Percent Solids without Unstabilized Solids	Option 8 - >75% Percent Solids with Unstabilized Solids
Alternative 1 – Time and Temperature Regime (84369)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Alternative 2 – High pH and High Temperature (84369)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Alternative 3 – Other Processes (84369)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Alternative 4 – Unknown Processes (84369)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Alternative 5 – Composting (84397)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Alternative 5 – Heat Drying (84397)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Alternative 5 – Heat Treatment (84397)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Alternative 5 – Thermophilic Aerobic Digestion (84397)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Alternative 5 – Beta Ray Irradiation (84397)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Alternative 5 – Gamma ray Irradiation (84397)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Alternative 5 – Pasteurization (84397)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Alternative 6 - Approved Equivalent Process	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Class B Sewage Sludge (monitoring station 581)

Pathogen Reduction Alternative	84370 Vector Attraction Reduction Options									
	Option 1 -38% Volatile Solids Reduction	Option 2 -Anaerobic Bench Scale Analysis	Option 3 – Aerobic Bench Scale Analysis	Option 4 – Specific Oxygen Uptake Rate	Option 5 – Aerobic Time and Temperature	Option 6 – Alkali Addition	Option 7 – >75% Percent Solids without Unstabilized	Option 8 - >75% Percent Solids with Unstabilized	Option 9 – Land Injection	Option 10 – Immediate Incorporation
Alternative 1 - Geometric Mean of Seven Fecal Samples (84369)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Alternative 2 - Aerobic Digestion (46396)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Alternative 2 - Air Drying (46396)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Alternative 2 - Anaerobic Digestion (46396)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Alternative 2 – Composting (46396)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Alternative 2 - Lime Treatment (46396)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Alternative 3 – Approved Equivalent Process	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

- (b) Has amount of sludge generated changed significantly since the last inspection..... N
- (c) How much sludge storage is provided at the plant.....
- (d) Records kept in accordance with State and Federal law (5 years according to OAC 3745-40-06)..... Y
- (e) Any complaints received in last year regarding sludge..... N
- (f) 5/8" screen at headworks for facilities that land apply sludge..... Y
- (g) Are sludge application sites inspected to verify compliance with NPDES permit..... N/E
- (h) Is a contractor used for sludge disposal..... Y
 If so, what is the name of the contractor.....

Comments/Status:

Section I: Self-Monitoring Program

Flow Measurement:

- (a) Primary/Secondary flow measuring devices (e.g. weir with ultrasonic level sensor):

Ultra Sonic

- (b) Flow meter calibrated annually Y
(Date of last calibration: 1/14/11)
- (c) 24-hour recording instruments operated and maintained..... Y
- (d) Flow measurement equipment adequate to handle full range of flows..... Y
- (e) All discharged flow is measured..... Y

Comments/Status:

Section I: Self-Monitoring Program (con't)

Sampling:

- (a) Sampling location(s) are as specified by permit..... Y
- (b) Parameters and sampling frequency agree with permit..... Y
- (c) Permittee uses required sampling method..... Y
(see GLC page)
- (d) Monitoring records (i.e., flow, pH, DO) maintained for a minimum of three years including all original strip chart recordings (i.e, continuous monitoring instrumentation, calibration and maintenance records)..... Y

Comments/Status:

The influent samples are collected after the fine screen but before aeration. The facility does not perform sampling more frequently that required by their permit. The facility does not monitor for parameters other than those required by the permit.

Section I: Self-Monitoring Program (con't)

Laboratory:

General

- (a) Does the Quality Assurance Manual contain written Standard Operating Procedures (SOP's) for all analysis performed onsite..... Y
- (b) Do SOP's include the following if applicable..... Y
 - Title
 - Scope and Application
 - Summary
 - Sample Handling and Preservation
 - Interferences
 - Apparatus and Materials
 - Reagents
 - Procedure
 - Calculations
 - Quality Control
 - Maintenance
 - Corrective Action
 - Reference (Parent Method)

Note: Standard Methods 1020A establishes that "Quality assurance (QA) is the definitive program for laboratory operation that specifies the measure required to produce defensible data of known precision and accuracy. Standard operating procedures are to be used in the laboratory in sufficient detail that a competent analyst unfamiliar with the method can conduct a reliable review and/or obtain acceptable results." SOPs should be developed for each analytical procedure.

- (c) EPA approved analytical testing procedures used (40 CFR 136.3).. Y
- (d) If alternate analytical procedures are used, proper approval has been obtained..... N/A
- (e) Analyses being performed more frequently than required by permit. N
- (f) If (e) is yes, are results in permittee's self-monitoring report..... N/A
- (g) Satisfactory calibration and maintenance of instruments/equipment. Y
(see score from GLC page)
- (h) Commercial laboratory used..... Y
Parameters analyzed by commercial lab: All but pH, Temperature, DO, CBOD, and TSS

Lab name: Belmont Labs

Discharge Monitoring Report Quality Assurance (DMRQA)

- (a) Participation in latest USEPA quality assurance performance sampling..... N
Date:
- (b) Were any parameters "Unsatisfactory"..... N/A
- (c) Reasons for "Unsatisfactory" parameters.....

Comments/Status:

The facility will need to customize the SOP for pH. The SOP for the CBOD analysis will need to be updated to include DO.

Section J: Effluent/Receiving Water Observations

Outfall # 001

Outfall Description: The discharge point was free of solids deposition, and there was not excessive algae present in the receiving stream.

Receiving Stream: Unnamed tributary of Little Twin Creek

Receiving Stream Description:

Comments/Status:

The location for the automated sampler and for the location that the samples would be collected was discussed. It was determined that the 24 hour composite samples would need to be collected after the step aeration but before the entering the receiving stream.

Section K: Multimedia Observations

- (a) Are there indications of sloppy housekeeping or poor maintenance in work and storage areas or laboratories..... N
- (b) Do you notice staining or discoloration of soils, pavement or floors.. N
- (c) Do you notice distressed (unhealthy, discolored, dead) vegetation.. N
- (d) Do you see unidentified dark smoke or dust clouds coming from sources other than smokestacks..... N
- (e) Do you notice any unusual odors or strong chemical smells..... N
- (f) Do you see any open or unmarked drums, unsecured liquids, or damaged containment facilities..... N

If any of the above are observed, ask the following questions:

- (1) What is the cause of the condition?
- (2) Is the observed condition or source a waste product?
- (3) Where is the suspected contaminant normally disposed?
- (4) Is this disposal permitted?
- (5) How long has the condition existed and when did it begin?

Comments/Status:

Permit # : 1PB00010*MD
NPDES #: OH0020770

ATTACHMENT 1

EFFLUENT LIMIT VIOLATION (Period of Review: October 1, 2010 – December 1, 2011)

Reporting Period	Parameter	Limit Type	Limit	Reported Value	Violation Date
May 2011	Fecal Coliform	Weekly Conc	2,000	27,000	5/22/2011

General Lab Criteria

Village of Farmersville WWTP January 11, 2012

Criteria	Standard Methods Requirement	Acceptable?		Rating
Balance				NR
• Standard Weights	• Either NIST Class s or ASTM/ANSI Class 1 weights ^{1,2}	<input type="checkbox"/> Yes	<input type="checkbox"/> No	
• Calibration Frequency / Documentation	• Calibration verification required at least once each day the balance is used. ³	<input type="checkbox"/> Yes	<input type="checkbox"/> No	
• Cleanliness, air movement, vibration	• Cleanliness of balance is a must and air movement and vibration needs to be kept to a minimum ¹	<input type="checkbox"/> Yes	<input type="checkbox"/> No	
• Other	• Service and recalibrate annually (manufacturer representative or comparable) ¹	<input type="checkbox"/> Yes	<input type="checkbox"/> No	
	• Must be able to measure to 0.1 grams ⁴	<input type="checkbox"/> Yes	<input type="checkbox"/> No	
	• Instrument manual available	<input type="checkbox"/> Yes	<input type="checkbox"/> No	
	• Log book maintained ²	<input type="checkbox"/> Yes	<input type="checkbox"/> No	

Comments: :

Criteria	Standard Methods Requirement	Acceptable?		Rating
Drying Oven (Suspended Solids)				NR
• Temperature Recordkeeping	• Temperature recorded with each use ⁴	<input type="checkbox"/> Yes	<input type="checkbox"/> No	
	• Log book maintained ²	<input type="checkbox"/> Yes	<input type="checkbox"/> No	
• Calibration Frequency / Documentation	• Thermometer calibrated annually with NIST traceable thermometer ^{1,2} . Correction factor posted on thermometer / equipment ¹	<input type="checkbox"/> Yes	<input type="checkbox"/> No	
• Other	• Thermometer temperature accurate to 0.5° Celsius ⁵	<input type="checkbox"/> Yes	<input type="checkbox"/> No	
	• Acceptable temperature range is 103° – 105° C ⁴	<input type="checkbox"/> Yes	<input type="checkbox"/> No	
	• Instrument manual available	<input type="checkbox"/> Yes	<input type="checkbox"/> No	

Comments: :

General Lab Criteria

Village of Farmersville WWTP January 11, 2012

Criteria	Standard Methods Requirement	Acceptable?		Rating
pH Meter				
<ul style="list-style-type: none"> • Calibration Frequency / Documentation 	<ul style="list-style-type: none"> • Calibration verification required for testing over long period of time (e.g. 12 hrs.), or after a large number of samples (every 10 samples)³ 	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	M
	<ul style="list-style-type: none"> • Logbook maintained² 	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	
<ul style="list-style-type: none"> • Minimum of 2 point calibration 	<ul style="list-style-type: none"> • Calibration per manufacturer specification and calibration buffers must bracket anticipated result⁷ 	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	
<ul style="list-style-type: none"> • Slope Documentation / Acceptability 	<ul style="list-style-type: none"> • Slope acceptable range indicated on benchsheet² 	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	
<ul style="list-style-type: none"> • Buffer Expiration Date 	<ul style="list-style-type: none"> • Buffers must not be expired 	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	
<ul style="list-style-type: none"> • Other 	<ul style="list-style-type: none"> • Instrument manual available 	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	
	<ul style="list-style-type: none"> • Teflon covered magnetic stirrer or equivalent for mixing⁸ 	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	

Comments:

The facility needs to add the expiration date to the pH buffer storage containers. The facility will need to customize the SOP for this analysis.

Criteria	Standard Methods Requirement	Acceptable?		Rating
Dissolved Oxygen Meter				
<ul style="list-style-type: none"> • Calibration Method 	<ul style="list-style-type: none"> • Air or known DO calibration method¹⁰ 	<input type="checkbox"/> Yes	<input type="checkbox"/> No	NR
	<ul style="list-style-type: none"> • Calibration per manufacturer specification¹⁰ 	<input type="checkbox"/> Yes	<input type="checkbox"/> No	
<ul style="list-style-type: none"> • Calibration Frequency / Documentation 	<ul style="list-style-type: none"> • Logbook maintained² 	<input type="checkbox"/> Yes	<input type="checkbox"/> No	
	<ul style="list-style-type: none"> • Calibration verification required at least once each day the meter is used.³ 	<input type="checkbox"/> Yes	<input type="checkbox"/> No	
<ul style="list-style-type: none"> • Other 	<ul style="list-style-type: none"> • Small to no bubble present under membrane (must be smaller than the lead in number 2 pencil)¹¹ 	<input type="checkbox"/> Yes	<input type="checkbox"/> No	
	<ul style="list-style-type: none"> • Instrument manual available 	<input type="checkbox"/> Yes	<input type="checkbox"/> No	

Comments:

General Lab Criteria

Village of Farmersville WWTP January 11, 2012

Criteria	Standard Methods Requirement		Rating
Incubator (CBOD/ E-Coli)		Acceptable?	NR
• Temperature Recordkeeping	• Temperature checked / recorded twice daily for each shelf in use ¹ (E-Coli)	<input type="checkbox"/> Yes <input type="checkbox"/> No	
	• Temperature checked / recorded daily ² (CBOD)	<input type="checkbox"/> Yes <input type="checkbox"/> No	
	• Acceptable temperature range (CBOD) is 20° C ±1.0° ¹²	<input type="checkbox"/> Yes <input type="checkbox"/> No	
	• Acceptable temperature range (E-Coli) is 35° C ±0.5° ²²	<input type="checkbox"/> Yes <input type="checkbox"/> No	
	• Logbook maintained ²	<input type="checkbox"/> Yes <input type="checkbox"/> No	
• Temperature Calibration / Documentation	• Thermometer calibrated annually with NIST traceable thermometer ^{1,2}	<input type="checkbox"/> Yes <input type="checkbox"/> No	
	• Temperature correction information posted on incubator ¹	<input type="checkbox"/> Yes <input type="checkbox"/> No	
• E-Coli can use multiple tubes (five 20 ml or ten 10 ml), or mfg's multi-well tray	• E-coli Ultraviolet lamp (365 nm wave length, 6 W bulb) ²³	<input type="checkbox"/> Yes <input type="checkbox"/> No	
• Other	• Instrument manual available	<input type="checkbox"/> Yes <input type="checkbox"/> No	
	• Temperature Log (thermometer accurate to 0.5 Celsius). ¹	<input type="checkbox"/> Yes <input type="checkbox"/> No	

Comments :

Criteria	Standard Methods Requirement		Rating
Refrigerator		Acceptable?	M
• Temperature Recordkeeping	• Temperature Log (thermometer accurate to 0.5 Celsius). ⁵	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
• Temperature Calibration / Documentation	• Thermometer calibrated annually with NIST traceable thermometer ^{1,2}	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
• Other	• Thermometer held in water bath. ¹	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
	• Refrigerator temperature ≤6° Celsius. ¹³	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
	• Do not store volatile solvents, food, or beverages. ¹⁴	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	

Comments:

The facility has a procedure for calibrating the thermometer with an NIST traceable thermometer but unfortunately the NIST traceable thermometer calibration recently expired. The facility should post a sign on the refrigerator that it is not to be used for the storage of food, beverages, or solvents.

General Lab Criteria

Village of Farmersville WWTP January 11, 2012

Criteria	Standard Methods Requirement	Acceptable?		Rating
Chlorine Meter				NR
• Calibration Frequency / Documentation	• pH / millivolt meter read to 0.1 mV ¹⁵	<input type="checkbox"/> Yes	<input type="checkbox"/> No	
	• Calibration verification required for testing over long period of time (e.g. 12 hrs.), or after a large number of samples (every 10 samples) ³	<input type="checkbox"/> Yes	<input type="checkbox"/> No	
• Calibration Method	• Calibration using three iodate solutions 0.2, 1.0, 5.0 milliliters or calibration per manufacturer specification ¹⁶	<input type="checkbox"/> Yes	<input type="checkbox"/> No	
	• Standards used for calibration not expired	<input type="checkbox"/> Yes	<input type="checkbox"/> No	
• Slope Documentation / Acceptability	• Calibration curve (acceptable slope)	<input type="checkbox"/> Yes	<input type="checkbox"/> No	
• Other	• Electrode free of deposits and foreign material	<input type="checkbox"/> Yes	<input type="checkbox"/> No	
	• Log book being maintained. ²	<input type="checkbox"/> Yes	<input type="checkbox"/> No	
	• Instrument manual available	<input type="checkbox"/> Yes	<input type="checkbox"/> No	
Comments: :				

Criteria	Standard Methods Requirement	Acceptable?		Rating
Ammonia Meter				NR
• Calibration Frequency / Documentation	• Calibration verification required for testing over long period of time (e.g. 12 hrs.), or after a large number of samples (every 10 samples) ³	<input type="checkbox"/> Yes	<input type="checkbox"/> No	
	• Log book being maintained ²	<input type="checkbox"/> Yes	<input type="checkbox"/> No	
• Slope acceptability	• Verify calibration slope is acceptable (per mfg. spec.).	<input type="checkbox"/> Yes	<input type="checkbox"/> No	
• Calibration Method	• Standards used for calibration (3 ammonia solutions of 10 mg/l, 1 mg/l, and 0.1 mg/l) or per mfg. spec. ¹⁷	<input type="checkbox"/> Yes	<input type="checkbox"/> No	
	• Standards used for calibration not expired	<input type="checkbox"/> Yes	<input type="checkbox"/> No	
• Other	• Electrode free of deposits and foreign material	<input type="checkbox"/> Yes	<input type="checkbox"/> No	
	• Teflon covered magnetic stirrer or equivalent for mixing ¹⁸	<input type="checkbox"/> Yes	<input type="checkbox"/> No	
	• Instrument manual available	<input type="checkbox"/> Yes	<input type="checkbox"/> No	
Comments: :				

General Lab Criteria

Village of Farmersville WWTP January 11, 2012

Criteria	Standard Methods Requirement		Rating
Sample Collection/Handling	Acceptable?		
• Sample Labeling	• Samples container labeled (description, date, time, preservative added, initialed). ¹⁹	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	M
• Chain of Custody	• Chain of custody (description, date, time, signature). ¹⁹	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
• Other	• Composite samples refrigerated during sample collection ¹⁴	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
	• Equipment blanks utilized ¹⁴	<input type="checkbox"/> Yes <input type="checkbox"/> No	
	• SOP for cleaning of sampling equipment	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
	• Logbook being maintained ²	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	

Comments:

The facility does not have a written SOP for the cleaning of the sampling equipment. The facility utilizes tamper tape on their sampling bottles but does not have a written procedure regarding the use of tamper tape. The facility currently uses 3 grab samples to collect their composite samples. The facility intends to purchase an automatic in the near future. The facility will need to make sure that the automatic sampler installation will collect samples proportional to the flow.

Criteria	Standard Methods Requirement		Rating
Desiccator	Acceptable?		
• General criteria	• Properly working seals.	<input type="checkbox"/> Yes <input type="checkbox"/> No	NR
	• Desiccant fresh (blue color)	<input type="checkbox"/> Yes <input type="checkbox"/> No	
• Documentation	• Log book being maintained ²	<input type="checkbox"/> Yes <input type="checkbox"/> No	

Comments:

Criteria	Standard Methods Requirement		Rating
Bench sheets	Acceptable?		
• General criteria	• Date(s) ²	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	A
	• Analyst initials ²	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
	• Blue or black ink pen ²	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
	• Calibration information ²	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
	• Equations, calculations, units for all measurements, notations, and results present ²	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
	• Corrections, single line through, initialed and dated ²	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	

Comments:

General Lab Criteria

Village of Farmersville WWTP January 11, 2012

Criteria	Standard Methods Requirement	Acceptable?		Rating
Hot Water Bath (Fecal Coliform/E. Coli)				
• Temperature Recordkeeping	• Temperature Log (thermometer accurate to 0.2° C) ²¹	<input type="checkbox"/> Yes	<input type="checkbox"/> No	NR
	• Incubator temperature 44.5° C ± 0.2° ^{21/24}			
• Temperature Calibration / Documentation	• Thermometer calibrated annually with NIST traceable thermometer ^{1,2}	<input type="checkbox"/> Yes	<input type="checkbox"/> No	
	• Log book being maintained ²	<input type="checkbox"/> Yes	<input type="checkbox"/> No	
• Water Level	• Thermometer total immersion or partial (line on thermometer to ID immersion depth) ^{1,5}	<input type="checkbox"/> Yes	<input type="checkbox"/> No	

Comments:

Criteria	Standard Methods Requirement	Acceptable?		Rating
Autoclaves/Steam Sterilizers				
• All apparatus utilized is adequately sterilized before use	• Sterilizing temperature 121° C ²⁵	<input type="checkbox"/> Yes	<input type="checkbox"/> No	NR
	• 10 to 30 minutes time based on material being sterilized ²⁶	<input type="checkbox"/> Yes	<input type="checkbox"/> No	
• Documentation	• Verify the autoclave temperature weekly by using a maximum registering thermometer (MRT) to confirm that 121°C has been reached as measured in the exhaust. ¹	<input type="checkbox"/> Yes	<input type="checkbox"/> No	
	• Date, contents, sterilization time and temperature, total time in autoclave, and analyst's initials should be recorded each time the autoclave is used ¹	<input type="checkbox"/> Yes	<input type="checkbox"/> No	
• Temperature Calibration / Documentation	• Thermometer calibrated annually with NIST traceable thermometer ^{1,2}	<input type="checkbox"/> Yes	<input type="checkbox"/> No	
	• Log book being maintained ²	<input type="checkbox"/> Yes	<input type="checkbox"/> No	
• Performance Checks	• Test monthly for efficacy using a biological such as commercially available <i>Geobacillus stearothermophilus</i> in spore strips, suspensions, or capsules ¹	<input type="checkbox"/> Yes	<input type="checkbox"/> No	

Comments:

General Lab Criteria

Village of Farmersville WWTP January 11, 2012

Criteria	Standard Methods Requirement	Rating								
Final Effluent Temperature Monitoring		Acceptable?								
<ul style="list-style-type: none"> • General Criteria 	<ul style="list-style-type: none"> • Thermometer calibrated annually with NIST traceable thermometer ^{1,2} 	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No								
	<ul style="list-style-type: none"> • Thermometer accurate to 0.1° Celsius⁵ 	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No								
	<ul style="list-style-type: none"> • Log book being maintained ² 	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No								
M										
Comments: The facility uses the build in thermometer on the DO meter for measuring temperature on the final effluent. The facility has not calibrated the thermometer for the DO meter.										
Number of Criteria Rated:		<table border="1" style="margin: auto; border-collapse: collapse;"> <tr><td style="background-color: #e0e0e0;">Acceptable</td><td style="text-align: center;">1</td></tr> <tr><td style="background-color: #e0e0e0;">Marginal</td><td style="text-align: center;">4</td></tr> <tr><td style="background-color: #e0e0e0;">Unacceptable</td><td style="text-align: center;">0</td></tr> <tr><td style="background-color: #e0e0e0;">Total Number of Areas Rated</td><td style="text-align: center;">5</td></tr> </table>	Acceptable	1	Marginal	4	Unacceptable	0	Total Number of Areas Rated	5
Acceptable	1									
Marginal	4									
Unacceptable	0									
Total Number of Areas Rated	5									
Acceptable Ratings – No action required (recommend SOP's written or updated, perform DMRQA's for all onsite analysis, recommend voluntary lab analyst certification, written response not required).										
Marginal Ratings – Improvements required, written response required (recommend SOP's be written or updated, recommend they perform DMRQA's for all onsite analysis, recommend voluntary lab analyst certification, require deficiencies to be addressed in written response).										
Unsatisfactory Rating - Improvements required, written response required, NOV issued (recommend SOP's be written or updated, recommend they perform DMRQA's for all onsite analysis, recommend voluntary lab analyst certification, require deficiencies to be addressed in written response to NOV).										
Consider recommending PAI Audit from DES when:	<ul style="list-style-type: none"> >60% of ratings are Marginal >45% of ratings are a combination of Marginal or Unacceptable >30% of ratings are Unacceptable 									

Notation of Referenced Method

- | | |
|--|--|
| <ul style="list-style-type: none"> 1 Method 9020-B, Item 3 2 Method 1020-A, Item 1 3 Method 1020-B, Item 10 4 Method 2540-B, Item 2 5 Method 2550-B, Item 1 6 Method 1020-A, Item 1 7 Method 4500-H B, Item 4 8 Method 4500-H B, Item 2 9 Method 1020-B, Item 2 10 Method 4500-O B, Item 3 11 Method 4500-O G, Item 3 12 Method 5210-B, Item 5 13 CFR 136.3, Table II | <ul style="list-style-type: none"> 14 Method 1060A, Item 1 15 Method 4500-CI I, Item 2 16 Method 4500-CI I, Item 4 17 Method 4500-NH3 D, Item 4 18 Method 4500-NH3 D, Item 2 19 Method 1060-B, Item 2 20 Method 1060-B, Item 1 21 Method 9222D, Item 1 22 Method 9223 B, Item 2 23 Method 9223 B, Item 3 24 Method 1603, Item 2 25 Method 9030-B, Item 3 26 Method 9020 B, Table IV |
|--|--|

General Lab Criteria

Village of Farmersville WWTP January 11, 2012

Equipment Logbook Content - all maintenance performed on a piece of equipment should be documented in the logbook. This should include parts replacement and routine maintenance activities. Entries should include date, maintenance performed and initials of person making entry.

Preservation and Holding Times

Parameter	Container	Min. Sample Size (mL)	Sample Type	Preservation	Maximum Storage Time	
					Recommended	Regulatory
BOD / CBOD	P, G	1000	G, C	Refrigerate $\leq 6^{\circ}\text{C}$	6h	48h
TSS	P, G	200	G, C	Refrigerate $\leq 6^{\circ}\text{C}$	7 d	7 d
pH	P, G	50	G	Analyze immediately	0.25h	0.25 h
NH3-N	P, G	500	G, C	Analyze as soon as possible or add H_2SO_4 to pH <2, Refrigerate $\leq 6^{\circ}\text{C}$	7 d	28 d
TRC	P, G	500	G	Analyze immediately	0.25h	0.25 h
DO (electrode)	G, BOD Bottle	300	G	Analyze immediately	0.25h	0.25 h
Temperature	P, G	--	G	Analyze immediately	0.25h	0.25 h
Metals, general	P, G	1000	G, C	For dissolved filter immediately and add HNO_3 to pH <2	6 months	6 months
Purgeables by purge and trap	G (PTFE lined lid)	40 (X2)	G	HCl to pH <2, Refrigerate $\leq 6^{\circ}\text{C}$	7 d	14 d
Base/Neutrals and acids	G (solvent rinsed or baked)	1000	C, G	Refrigerate $\leq 6^{\circ}\text{C}$	7 d	7 days until extraction 40 days after extraction
Pesticides	G (PTFE lined lid)	1000	C	Refrigerate $\leq 6^{\circ}\text{C}$	7 d	7 days until extraction 40 days after extraction
Fecal Coliform / E-Coli	G, P (Sterilized)	100	G	Refrigerate $\leq 10^{\circ}\text{C}$ If chlorine present, add sodium thiosulfate tablet	6 hrs transport Start analysis within 2 hrs of receipt in lab.	
Oil and Grease	G	1000	G	HCl or H_2SO_4 to pH <2, Refrigerate $\leq 6^{\circ}\text{C}$	28 d	28 d

Approved Standard Methods

CBOD / BOD 5 Day	Std Methods 5210-B
Ammonia, Selective Electrode Method	Std Methods 4500-NH3 D
Total Residual Chlorine, DPD Colorimetric Method	Std Methods 4500-Cl G
Total Suspended Solids, Dried at 103-105 °C	Std Methods 2540-D
Dissolved Oxygen, Membrane Electrode Method	Std Method 4500-O G
pH, Electrometric Method	Std Methods 4500-H+ B
Fecal Coliform, Membrane Filter Procedure	Std Methods 9222D
Escherichia Coli, Enzyme Substrate Test	Std Method 9223B
Escherichia Coli Membrane Filtration Procedure	EPA Method 1603
Oil and Grease	USEPA 1664A or Std Methods 5520B
Metals, general	USEPA 200, Std Methods 3111B or C, or 3120B
Volatiles (Purgeables by purge and trap)	USEPA 6210, Std Methods 624
Semi-Volatiles (Base/Neutrals and acids)	USEPA 6410, Std Methods 625
Pesticides	USEPA 6410 and 6630, Std Methods 608