Ohio | Environmental Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

January 13, 2012

Mr. Jim Sexstone
YMCA Camp Campbell Gard
P.O. Box 13029
Hamilton, Ohio 45011

Re: Butler County, YMCA Camp Campbell Gard, NPDES Permit Violations

Dear Mr. Sexstone:

We have reviewed your Discharge Monitoring Reports (DMRs) covering the months of May 2010 through November 2011 for the referenced facility. Our review indicates violations of the conditions of your NPDES Permit (NPDES Permit # OH0131865; OEPA 1PR00111*BD). The specific instances of noncompliance and deficiencies were as follows:

Effluent Limit Violations for May 2010 through November 2011					
Reporting Period	Parameter	Limit Type	Units	Permit Limit	Reported Value
February 2011	CBOD5	Monthly	mg/l	10	11
February 2011	CBOD5	Daily	mg/l	15	31
July 2011	pH	Daily	S.U.	6.5	6.0

In addition, an annual sludge disposal report is required to be submitted by January 31 of each year. This requirement is address in Part II, Section M of the NPDES Permit. The report addressing sludge disposal for 2010 has not been submitted as required. Please submit this report immediately.

Finally, the current NPDES Permit expires on August 31, 2012. The NPDES Permit renewal application will be required to be submitted by February 29, 2011.

Please be advised that failure to comply with the effluent limitations or to satisfy the reporting requirements of your NPDES Permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

Please inform this office, in writing, by January 27, 2012 as to the reasons for the above referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or

Southwest District Office
401 East Fifth Street
Dayton, OH 45402-2911

937 | 285 6357
937 | 285 6249 (fax)
www.epa.ohio.gov

proposed, for completion of the actions. Future violations must be reported as required by the NPDES Permit as detailed in Part III.12 titled "Noncompliance Notification."

If you have any questions regarding the above, please contact me at (937) 285-6096.

Sincerely,

Ned Sarle
Division of Surface Water
Permit Section

ec: Tim Poynter, Poynter Waste Water Services, LLC