



Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

January 24, 2012

Wayne Mobile, Inc.
Attn: Mr. Dale Dakin
P.O. Box 613
Waynesville, OH 45068

**Re: Wayne Mobile Inc- 1PV00113*AD
Notice of Violation**

Dear Permittee:

A compliance review was conducted on your Discharge Monitoring Report (DMR) submitted on January 19, 2012. As detailed at the end of this letter, screening of your submitted DMR has identified compliance issues.

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES Permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

Please inform this office, in writing, within ten days of receipt of this notification as to the reasons for the above referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions. Future violations must be reported as required by the NPDES Permit as detailed in Part III.12 titled "Non-compliance Notification".

If you should have any questions, feel free to contact me by phone at (937) 285-6029 or by electronic mail at Joshua.Jackson@epa.state.oh.us.

Respectfully,

Joshua Jackson
Environmental Specialist II
Division of Surface Water

Ec: atipton@waynesville-ohio.org



**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

Notice of Violation Report

Facility: Wayne Mobile Inc

Permit No.: 1PV00113*AD

Report Period: December 2011

Date Received: 1/19/2012

Station	Type	Date	Reporting Code	Parameter	Limit Type	Permit Limit	Reported Value
001	Limit	12/4/2011	00300	Dissolved Oxygen	Daily Conc.	6.0	3.
001	Limit	12/12/2011	00300	Dissolved Oxygen	Daily Conc.	6.0	2.3
001	Limit	12/16/2011	00300	Dissolved Oxygen	Daily Conc.	6.0	2.6
001	Limit	12/21/2011	00300	Dissolved Oxygen	Daily Conc.	6.0	2.2
001	Limit	12/27/2011	00300	Dissolved Oxygen	Daily Conc.	6.0	2.4