Ohio | Environmental Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

January 20, 2012

Ray Ruess
Woodlands Reception Hall
9680 Cilley Road
Cleves, Ohio 45002

RE: Woodlands WWTP
NPDES Permit 1PX00030*BD, OH0132161
Notice of Violation

Dear Mr. Ruess:

I have conducted a compliance review of this wastewater treatment plant for the past 6 months. My review indicates several violations of the conditions of the NPDES permit for the facility. The specific instances of non-compliance are as follows:

EFFLUENT LIMIT VIOLATION AT OUTFALL 1PX00030001

Parameter	Date	Permit Limit	Value Reported
Fecal Coliform	6/1/2011	1000 counts	1150 counts

REPORTING CODE VIOLATION AT OUTFALL 1PX00030001

Parameter	Date	Reporting Code Used	Explanation
Fecal Coliform	9/16/2011	AB (data lost)	none

A non-compliance notification was not sent to this agency regarding the above violations, as required by the conditions in the permit. A written non-compliance notification should be sent to me whenever there is a limit violation, plant upset, bypass or monitoring violation.

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

Southwest District Office
401 East Fifth Street
Dayton, OH 45402-2911

937 | 285 6357
937 | 285 6249 (fax)
www.epa.ohio.gov

A response to this Notice of Violation is required by February 3, 2012 discussing the causes of the listed violations and actions that will be taken to prevent their reoccurrence. If you have any questions about this letter, please contact me at (937) 285-6101.

Sincerely,

Mary Osika
Environmental Specialist
Division of Surface Water

ec: Winelco, Inc.