



**Environmental  
Protection Agency**

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

January 24, 2012

**Re:** Belmont County  
City of St. Clairsville  
West Wastewater Treatment Plant  
Notice of Violation  
NPDES Permit 0PA00099\*FD  
Correspondence (PWW)

Mayor Robert Vincenzo and City Council  
City of St. Clairsville  
100 N. Market Street  
P.O. Box 537  
St. Clairsville, Ohio 43950

Dear Mayor and Council Members:

We have received your self-monitoring reports covering the months of January through November 2011 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Reporting Period	Station	Parameter	Limit Type	Limit	Reported Value	Violation Date
July 2011	001	Dissolved Oxygen	1D Conc	5	4.2	7/7/2011

**Notes:** 1D Conc = Daily Average Concentration Value  
1D Qty = Daily Average Loading Value  
7D Conc = Weekly Average Concentration Value  
30D Conc = Monthly Average Concentration Value  
7D Qty = Weekly Average Loading Value  
30D Qty = Monthly Average Loading Value

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

We have reviewed your report addressing the reasons for the above violations and the actions being taken to prevent further occurrences. Hopefully, these actions will prevent any recurrence so that enforcement action will not be required. No additional information is requested at this time.

If there are any questions, please contact me at (740) 380-5284.

Sincerely,

A handwritten signature in blue ink, appearing to read 'Abbot Stevenson', with a long horizontal flourish extending to the right.

Ms. Abbot Stevenson  
Environmental Engineer  
Permits and Enforcement Section  
Division of Surface Water

AS/dh

c: Doug Frye, Supt.